

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 11492

PRINT OR TYPE ONLY

1. OWNER DOUG COLEMAN ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 710 Bowles Lane 2665 Billys Road  
Gardnerville, NV 89110 Minden, Nevada

2. LOCATION SE  $\frac{1}{4}$  SW  $\frac{1}{4}$  Sec. 32 T. 14 \*S.R. 20 E. Douglas County  
 PERMIT NO. 21-020-30 Parcel No. None Subdivision Name \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other  Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Overburden, clay and fine sand		0	5	5
Sand, medium to fine		5	30	25
D.G. sand, medium grain, very compact		30	97	67
Clay, tight, with fine sand lenses		97	103	6
Gravels, medium to course with sand, DG, and thin lenses of clay	xx	103	140	37
T.D.-----140 ft				

Note: Blank below perforations is filled with pea gravel to hold back sand, etc

JUL 27 1990  
 STATE ENGINEER

8. WELL CONSTRUCTION

Diameter 11 3/4 inches Total depth 140 feet

Casing record 6 5/8" steel  
 Weight per foot 13.3 Thickness .188

Diameter	From	To
<u>6 5/8</u> inches	<u>plus 2</u> feet	<u>140</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type Concrete  
 Depth of seal 100 feet  
 Gravel packed: Yes  No   
 Gravel packed from 100 feet to 140 feet

Perforations:  
 Type perforation Factory milled  
 Size perforation 3" x 3/32"  
 From 110 feet to 130 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started July 12, 1990  
 Date completed July 14, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
_____	_____	_____	_____
_____	_____	_____	_____

Flushed mud from well and gravel packed well  
 Developed well with air. Blowing 25 plus GPM from 50 feet. Developed well for 2 1/2 hrs

BAILER TEST

G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL

Static water level 12 feet below land surface  
 Flow 25 plus G.P.M. P.S.I. \_\_\_\_\_  
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A & H PUMP CO. Contractor  
 Address CARSON CITY, NEV 89701 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 23295  
 Nevada contractor's driller's number issued by the Division of Water Resources \_\_\_\_\_  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535  
 Signed Serald Shinnell By driller performing actual drilling on site or contractor  
 Date July 16, 1990