

OFFICE USE ONLY
 Log No. 34176
 Permit No. _____
 Basin. 8-103-104

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 14500

PRINT OR TYPE ONLY

1. OWNER Tom Gibbons ADDRESS AT WELL LOCATION Parcel #2 3901 Kings Canyon Rd
 MAILING ADDRESS 115 Division Carson City, NV
 2. LOCATION NW 1/4 NE 1/4 Sec. 23 T. 150 S R. 20 E. Carson City County Carson City
 PERMIT NO. 7-072-15 Parcel No. _____ Subdivision Name Kings Canyon Unit

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other HAID

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Overburden w/ boulders</u>		<u>0</u>	<u>14</u>	<u>14</u>
<u>Alluvial fill of clay loams, cemented</u>		<u>14</u>	<u>168</u>	<u>154</u>
<u>Tight clay, multi coloration</u>		<u>168</u>	<u>177</u>	<u>9</u>
<u>Boulders cemented w/ clay</u>		<u>177</u>	<u>187</u>	<u>10</u>
<u>Alluvial clay, hard</u>		<u>187</u>	<u>215</u>	<u>28</u>
<u>Cemented alluvial fill, hard to very hard</u>		<u>215</u>	<u>250</u>	<u>35</u>
<u>Granite fracture w/ very hard water</u>		<u>250</u>	<u>280</u>	<u>30</u>
T.D. <u>280</u>				

8. WELL CONSTRUCTION
 Diameter 10 3/4 inches Total depth 280 feet
9 3/4 inches
 Casing record Steel 6 7/8"
 Weight per foot 13.1 Thickness 1.88
 Diameter From To
6 7/8 inches +2 feet 280 feet
 Surface seal: Yes No Type concrete
 Depth of seal 600 feet
 Gravel packed: Yes No
 Gravel packed from 100 feet to 280 feet
 Perforations:
 Type perforation Factory M-11 slotted
 Size perforation 1/32" x 3"
 From 260 feet to 280 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 109 feet below land surface
 Flow 20-22 G.P.M. P.S.I. _____
 Water temperature Cold °F Quality good

Date started July 8 1990
 Date completed July 12 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>22</u>	<u>0.35</u>		
<u>Developed with air blowing 20 gpm from 180' with 250-450 gpm for 4 hours to clean & develop</u>			

90 BAILER TEST

G.P.M.	Draw down	feet	hours
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name H & H Pump Co Contractor
 Address Carson City NV 8901
 Nevada contractor's license number issued by the State Contractor's Board 23295
 Nevada contractor's driller's number issued by the Division of Water Resources _____
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1674
 Signed Joey Smith By driller performing actual drilling on site or contractor
 Date 7/12/90