

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 11801

1. OWNER Ken Deane ADDRESS AT WELL LOCATION 2905 LAKE & HORN DRIVE CARSON CITY NV  
 MAILING ADDRESS 2905 LAKE & HORN DRIVE CARSON CITY NV  
 2. LOCATION N 1/4, N 20 E 31 T 17N WASHO2 County WASHO  
 PERMIT NO. 50-330-05 Parcel No. WASHO VALLEY Subdivision Name

3. TYPE OF WORK New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/> Deepen <input type="checkbox"/> Other <input type="checkbox"/>	4. PROPOSED USE Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Municipal <input type="checkbox"/> Industrial <input type="checkbox"/>	5. TYPE WELL Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/> Other <input type="checkbox"/> <u>Mud</u>
--	---	--

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Dg Brown</u>		<u>0</u>	<u>13</u>	
<u>BROWN CLAY</u>		<u>13</u>	<u>22</u>	
<u>GRAY SAND</u>		<u>22</u>	<u>85</u>	
<u>GRAY CLAY</u>		<u>85</u>	<u>95</u>	
<u>SAND AND GRAVEL</u>	<u>106</u>	<u>95</u>	<u>110</u>	

8. WELL CONSTRUCTION

Diameter 8 1/4 inches Total depth 110 feet  
 \_\_\_\_\_ inches  
 \_\_\_\_\_ inches  
 Casing record \_\_\_\_\_  
 Weight per foot 14 Thickness 15.6  
 Diameter From To  
8 5/8 inches 0 feet 110 feet  
 \_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
 Surface seal: Yes  No  Type NEAT CEMENT PUMP  
 Depth of seal 5.5 feet  
 Gravel packed: Yes  No   
 Gravel packed from 5.5 feet to 110 feet  
 Perforations:  
 Type perforation MILL SLIT  
 Size perforation 3/22 x  
 From 100 feet to 110 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 9-6 1990  
 Date completed 9-10 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours

9. WATER LEVEL

Static water level 14 feet below land surface  
 Flow 100 G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality UNKNOWN

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name COSTCO DRILLING CO Contractor  
 Address 12000 S. VIRGINIA BEACH BLVD NV 89511 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 27767  
 Nevada contractor's driller's number issued by the Division of Water Resources 1600  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1600  
 Signed Kelly Winters By driller performing actual drilling on site or contractor  
 Date 9-11-90