

OFFICE USE ONLY
 Log No. 34196
 Permit No. _____
 Basin B-101

WELL DRILLER'S REPORT
 Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 11408

1. OWNER Donald W. Schmittlein ADDRESS AT WELL LOCATION 3455 Testolin Rd.
 MAILING ADDRESS 3455 Testolin Rd. Fallon, Nev. 89406
 FALLON, NEV. 89406

2. LOCATION SW 1/4 NW 1/4 Sec 9 T 18 N/S R. 29 E Churchill County
 PERMIT NO. N/A 1 Tom Robinson Parcel Map
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0	8	8
Coarse Brown Sand		8	23	15
Green Sand		23	41	18
Brown Clay		41	44	3
Brown Coarse Sand		44	52	8
Green & Black Sand		52	76	24
Green Coarse Sand		76	79	3
Brown Clay		79	81	2
Green Clay		81	84	3
Green Coarse Sand		84	86	2
Gray Clay		86	88	2
Green Coarse Sand		88	95	7
Green clay		95	107	12
Coarse Green Sand		107	111	4
Brown Clay		111	114	3
Coarse Brown Sand		114	119	5
Brown Sand		119	120	1
Brown Sand		120	148	28
Brown Coarse Sand		148	153	5
Brown Sand		153	155	2

90 SEP 12 10:49 AM RECEIVED STATE ENGINEERS OF NV

8. WELL CONSTRUCTION
 Diameter 12 inches Total depth 155 feet
 Casing record ASTM-A-53-A
 Weight per foot _____ Thickness _____
 Diameter From To
6-5/8 inches 0 feet 155 feet
 _____ inches _____ feet _____ feet

Surface seal: Yes No Type Cement
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 155 feet

Perforations:
 Type perforation Mill Cut
 Size perforation 1/8
 From 152 feet to 155 feet
 From _____ feet to _____ feet

Date started August 26, 1990
 Date completed September 1, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL
 Static water level 8 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Parsons Drilling, Inc.
 Contractor
 Address P.O. Box 1265 Fallon, NV. 89406
 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 29064
 Nevada contractor's driller's number issued by the Division of Water Resources 1454
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1715
 Signed Doug Parsons
 By driller performing actual drilling on site or contractor
 Date 10 SEP 1990