

*dda*

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 13943

1. OWNER Harold Hall ADDRESS AT WELL LOCATION 310 Pompe  
 MAILING ADDRESS 35 E. Fourth St  
Reno, Nv 89501

2. LOCATION SE  $\frac{1}{4}$  SE  $\frac{1}{4}$  Sec. 21 T. 21 N/S R. 19 E Washoe County  
 PERMIT NO. 86-305-02 - Lemmon Valley  
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other  Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown clay		0	19	19
Green white yellow sand with green clay		19	26	7
Brown clay with tan yellow white fine sands		26	73	47
Brown yellow white coarse sand trace of tan clay & gravels		73	135	62
Sticky brown clay		135	157	22
Tan yellow white sands		157	162	5
Sticky tan clay traces of D.G. sands		162	182	20
T.d. 182 feet				

8. WELL CONSTRUCTION  
 Diameter 10 inches Total depth 182 feet  
 \_\_\_\_\_ inches  
 \_\_\_\_\_ inches  
 Casing record 6 5/8 inches  
 Weight per foot 10.78 Thickness .156

Diameter	From	To
<u>6 5/8</u> inches	<u>+ 1 1/2</u> feet	<u>182</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type neat cement  
 Depth of seal 52 feet  
 Gravel packed: Yes  No   
 Gravel packed from 52 feet to 182 feet

Perforations:  
 Type perforation Stainless screen  
 Size perforation .040  
 From 130 feet to 140 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 1/2/90, 19\_\_\_\_  
 Date completed 1/3/90, 19\_\_\_\_

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>Blew with air to clean &amp; develop.</u>			

9. WATER LEVEL  
 Static water level 40 feet below land surface  
 Flow 20+ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Aqua Drilling & Well Service, Inc  
Contractor  
 Address 625 Spice Islands Dr Suite L Sparks, Nv  
Contractor 89431  
 Nevada contractor's license number issued by the State Contractor's Board 15291  
 Nevada contractor's driller's number issued by the Division of Water Resources 1132  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1511  
 Signed Roger M. Thrall  
By driller performing actual drilling on site or contractor  
 Date Roger M. Thrall 1/4/90

BAILER TEST

G.P.M.	Draw down	feet	hours