

OFFICE USE ONLY
 Log No. 34237
 Permit No. _____
 Basin 6-24
 NOTICE OF INTENT NO. 15577

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

1. OWNER Dan Sheline ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 5615 Dolores Rd 3860 Tree Farm Court
Sparks, Nv 89436 Lot 5 of Land Map 66 A
 2. LOCATION SE 1/4 SE 1/4 Sec 17 T 21 N/S R 22 E Washoe County
 PERMIT NO. 76-660-04 - Palomino Valley
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/> Air <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Overburden		0	5	5
Lt brown hard clay		5	67	62
White clay [sticky]		67	113	46
Gray & white clay with traces black volcanic rock		113	117	4
Black white green volcanic rock		117	160	43
T.D. 160 feet				

8.10" - 54' WELL CONSTRUCTION
 Diameter 8 1/2 inches Total depth 160 feet
 Casing record 6 5/8 inch
 Weight per foot 10.78 Thickness .156
 Diameter 6 5/8 inches From + 2 feet To 160 feet
 Surface seal: Yes No Type grout
 Depth of seal 51 feet
 Gravel packed: Yes No
 Gravel packed from 51 feet to 160 feet
 Perforations:
 Type perforation factory
 Size perforation 3/32 X 3
 From 120 feet to 140 feet
 From _____ feet to _____ feet

Date started 90 7/17/90, 19____
 Date completed 7/18/90, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew with air to clean and develop.			

9. WATER LEVEL
 Static water level 90 feet below land surface
 Flow 20+ G.P.M. Not Artesian P.S.I.
 Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling & Well Service, Inc.
 Address 625 Spice Islands Dr Suite L Sparks
89431
 Nevada contractor's license number issued by the State Contractor's Board 15291
 Nevada contractor's driller's number issued by the Division of Water Resources 1132
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1509
 Signed Roger M. Thrall
 By driller performing actual drilling on site or contractor
 Date 7/20/90

BAILER TEST

G.P.M.	Draw down	feet	hours
G.P.M.	Draw down	feet	hours
G.P.M.	Draw down	feet	hours