WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 34238
Permit No.
Basin 7-93

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. XXXX14780

1. OWNER SCOTT & TRACY CAMPBELL
MAILING ADDRESS P.O. Box 12073, Reno, NV 89510

ADDRESS AT WELL LOCATION 3050 Antelope Valley Road, Reno, NV 89506

2. LOCATION SW ~~NE~~ ¼ SE ¼ Sec. ~~10~~ 11 T. 22N N/S R. 19 E. Washoe County
PERMIT NO. (Issued by Water Resources) 79-500-~~198~~ 59 (Parcel No.) Antelope Valley Rock Estates #2 Rev. B (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐ Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown sand		1	4	3
Brown clay with DG		4	35	31
WEathered granite		35	69	34
Gray granite		69	139	70
FRacture	X	139	140	1
Gray granite		140	181	41
Soft zone, Fracture	X	181	185	4
Gray granite		185	200	5

'90 SEP 12 AM 10:49
STATE ENGINEER

Date started 8-29-90, 19
Date completed 8-30-90, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter 8 5/8 inches Total depth 200 feet
10 inches n 0---50 ft.
inches
Casing record 200 ft. steel casing installed.
Weight per foot Thickness .156

Diameter	From	To
6 5/8 inches	0 feet	200 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement grout
Depth of seal 51 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 200 feet

Perforations:
Type perforation factory sawed slot perforations
Size perforation 3/32 x 3 x 5 around
From 140 feet to 160 feet
From 180 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 88 feet below land surface
Flow 35 G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370, Reno, NV 89510 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada contractor's driller's number issued by the Division of Water Resources 908
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed Edward T. Mondragon (By driller performing actual drilling on site or contractor)
Date September 4, 1990

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627