WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 34239
Permit No.
Basin 7-93

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 15573

1. OWNER Paul & Sally Woodyatt
MAILING ADDRESS P. O. Box 60557
Reno, Nv 89506

ADDRESS AT WELL LOCATION 1245 Mineral Flat Rd
Lot 251

2. LOCATION NE ¼ NE ¼ Sec. 13 T. 22 N/S R. 19 E. Washoe County
PERMIT NO. ____ (Issued by Water Resources) 79-~~480-23~~ 481-27- (Parcel No.) Red Rock Est. #251 (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐ Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Tan yellow white D G		0	10	10
White & black D G		10	24	14
Tan brown yellow white D G		24	65	41
Tan brown yellow semi - decomposed granite		65	235	170
Black & white granite with traces of tan & brown		235	299	64
T.D. 299				

90 JUL 26 A9:35
STATE ENGINEER

Date started 7/17/90, 19
Date completed 7/19/90, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew with air to clean and develop.			

BAILER TEST
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours

8. 10" - 58' WELL CONSTRUCTION
Diameter 8½ inches Total depth 299 feet
____ inches
____ inches
Casing record 6 5/8 inch
Weight per foot 10.78 Thickness .156

Diameter	From	To
6 5/8 inches	+ 2 feet	299 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type grout
Depth of seal 53 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 53 feet to 299 feet

Perforations:
Type perforation factory
Size perforation 3/32 X 3
From 279 feet to 299 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 160 feet below land surface
Flow 20+ G.P.M. ____ P.S.I.
Water temperature cold °F Quality ____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Aqua Drilling & Well Service, Inc (Contractor)
Address 625 Spice Islands Dr Suite L Sparks 89431 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 15291
Nevada contractor's driller's number issued by the Division of Water Resources 1132
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1511
Signed [signature] (By driller performing actual drilling on site or contractor)
Date Roger M. Thrall 7/20/90

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627