

OFFICE USE ONLY
Log No. 34241
Permit No. _____
Basin 6-84

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 14643

1. OWNER Mike & Debbie Depoali ADDRESS AT WELL LOCATION 5705 Tartan
MAILING ADDRESS 4000 Rewana
Reno, Nv 89502

2. LOCATION SW 1/4 SW 1/4 Sec. 5 T. 22 N/S R. 21 E. Washoe County
PERMIT NO. 077-090-01 - Palomino Valley Subdivision Name 5-2-1-1
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
New Well Recondition
Deepen Other

4. PROPOSED USE
Domestic Irrigation Test
Municipal Industrial Stock

5. TYPE WELL
Cable Rotary
Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
D.G. brown		0	4	4
Multi-colored D.G. & fine brown sand		4	44	40
Brown clay & fine sand		44	82	38
Multi-colored D.G. w/some brown sticky clay & fine sand		82	92	10
Gray clay & fine sand		92	100	8
Gray sticky clay		100	176	76
Gray clay w/trace Blk white & green course sand & fine sand		176	186	10
Gray clay fine sand		186	200	14
White black green coarse sands		200	243	43
Blk white green sands green clay		243	397	154
White brown black green course sands		397	439	42
T.D. 439 ft				

8. 10" - 54' WELL CONSTRUCTION
Diameter 8 1/2 inches Total depth 439 feet
Casing record 6 5/8 inch
Weight per foot 10.78 Thickness .156
Diameter 6 5/8 inches From +1 feet To 439 feet
Surface seal: Yes No Type neat cement
Depth of seal 50 feet
Gravel packed: Yes No
Gravel packed from 50 feet to 439 feet

Perforations:
Type perforation factory
Size perforation 3/32 X 3
From 399 feet to 419 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Date started 8/13/90, 19____
Date completed 8/15/90, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew with air to clean and develop.			

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
G.P.M. _____ Draw down _____ feet _____ hours
G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL
Static water level 300 feet below land surface
Flow 20+ G.P.M. P.S.I.
Water temperature cool °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Aqua Drilling & Well Service, Inc.
Contractor
Address 625 Spice Islands Dr Suite L Sparks, Nv
Contractor 89431
Nevada contractor's license number 15291
issued by the State Contractor's Board
Nevada contractor's driller's number 1132
issued by the Division of Water Resources
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1509
Signed Roger M. Thrall
By driller performing actual drilling on site or contractor
Date Roger M. Thrall 8/16/90