WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

**Please complete this form in its entirety**

OFFICE USE ONLY
Log No. 34260
Permit No.
Basin 21-59

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 14279

1. OWNER Jon S Bisiaux 310 W. Second St. ADDRESS AT WELL LOCATION 1855 1725 E.
MAILING ADDRESS 70-5 Bt. Mt., Nv. 89820

2. LOCATION NW ¼ NE ¼ Sec. 9 T. 31 N N/S R. 45 E E. Lander County
PERMIT NO. N/A (Issued by Water Resources) N/A (Parcel No.) N/A (Subdivision Name)

3. TYPE OF WORK: New Well ☒ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☒ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☒ Rotary ☐ Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Soil Brown | | 0 | 2 | 2 |
| Clay Brown | | 2 | 4 | 2 |
| Sand+ Gravel Brown | | 4 | 29 | 25 |
| Sandy Clay Brown | | 29 | 49 | 20 |
| Clay Brown | | 49 | 60 | 11 |
| Sand + Gravel Brown | 11 | 60 | 71 | |
| Clay Blue | | 71 | 72 | 1 |

'90 SEP 10 A11:43 RECEIVED STATE ENGINEERS OFFICE

Date started 8-1-, 1990
Date completed 8-24-, 1990

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | | | |

BAILER TEST
G.P.M. 20 Draw down 25 feet 3 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter 6 inches Total depth 72 feet
10 inches To 508 feet
inches
Casing record
Weight per foot 14 Lbs. Thickness .188

| Diameter | From | To |
|---|---|---|
| 6 inches | 0 feet | 72 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation Torch
Size perforation 1/8" by 5"
From 62 feet to 72 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 11 feet below land surface
Flow Good G.P.M. P.S.I.
Water temperature 54 °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name T & R DRILLING (Contractor)
Address P.O. Box 1982 Wmca., Nv. 89445 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 017721
Nevada contractor's driller's number issued by the Division of Water Resources 1190
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1190
Signed Thomas [signature] (By driller performing actual drilling on site or contractor)
Date 9-4-1990

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627