WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 34288
Permit No.
Basin 4-51

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 14318

1. OWNER Newmont Gold Company
MAILING ADDRESS P.O. Box 669
Carlin, Nevada 89822-0669

ADDRESS AT WELL LOCATION Gold Quarry Mine,
Six Miles North of Carlin, Nevada

2. LOCATION SW ¼ SW ¼ Sec. 36 T. 34 (N)/S R. 51 E. Eureka County

PERMIT NO. Waiver M/O-246 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☒
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clayey Gravel (Fill)		0	4.0	4.0
Silty Clay		4.0	11.0	7.0
Sand	Yes	11.0	18.0	7.0
Clayey Gravel	Yes	18.0	22.0	4.0
Silty Sandstone	Yes	22.0	36.5	14.5
(SHB Boring GQE 215)				
~~Plugged: See Log #35125~~				

Date started June 3, 1990
Date completed June 4, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	N/A		

BAILER TEST
G.P.M. N/A Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours

8. WELL CONSTRUCTION
Diameter 6.5 inches Total depth 35.2 feet
____ inches
____ inches
Casing record Schedule 40 PVC, 6" Steel Monument
Weight per foot ____ Thickness ____

Diameter	From	To
2 inches	0 feet	35.2 feet
6 inches	0 feet	3.1 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement Grout above Bentonite
Depth of seal 16.4 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 16.4 feet to 35.2 feet

Perforations:
Type perforation Slotted
Size perforation 0.020"
From 18.2 feet to 35.0 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 15.7 feet below land surface
Flow ____ G.P.M. ____ P.S.I.
Water temperature Cool °F Quality ____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Sergent, Hauskins & Beckwith Engineers (Contractor)
Address 737 E. Glendale Avenue, Sparks, NV (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0029654
Nevada contractor's driller's number issued by the Division of Water Resources ____
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1687
Signed Paul T. Spillers (By driller performing actual drilling on site or contractor)
Date July 18, 1990

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627