WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 34289
Permit No.
Basin 4-51

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 14318

1. OWNER Newmont Gold Company
MAILING ADDRESS P.O. Box 669
Carlin, Nevada 89822-0669

ADDRESS AT WELL LOCATION Gold Quarry Mine,
Six miles North of Carlin, Nevada

2. LOCATION SE ¼ SW ¼ Sec. 36 T. 34 (N)S R 51 E Eureka County
PERMIT NO. Waiver M/O-246 (Issued by Water Resources) Parcel No. Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☒
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clayey Gravel(fill)		0	12.5	12.5
Clayey Gravel		12.5	23.0	10.5
Sandy Gravel		23.0	27.0	4.0
Silty Sandstone	Yes	27.0	39.7	12.7
(SHB Boring GQE 234)				

'90 JUL 19 A10:54
STATE ENGINEER

Date started June 29, 1990
Date completed June 30, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	N/A		

BAILER TEST
G.P.M. N/A Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours

8. WELL CONSTRUCTION
Diameter 4" inches Total depth 39.7' feet
____ inches
____ inches
Casing record 4" Schedule 40 PVC/8" Steel Monument
Weight per foot ____ Thickness ____

Diameter	From	To
4" inches	0 feet	39.7' feet
8" inches	0 feet	3.0' feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement grout above bentonite
Depth of seal 27.5 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 27.5 feet to 39.7 feet

Perforations:
Type perforation slotted
Size perforation .020"
From 29.5' feet to 39.5' feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 34.1' feet below land surface
Flow ____ G.P.M. ____ P.S.I.
Water temperature Cool °F Quality ____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Sergent, Hauskins & Beckwith Engineers (Contractor)
Address 737 E. Glendale Avenue, Sparks, NV (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0029654
Nevada contractor's driller's number issued by the Division of Water Resources ____
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1687
Signed Paul T. Spillers (By driller performing actual drilling on site or contractor)
Date July 18, 1990

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627