

OFFICE USE ONLY
 Log No. 34300
 Permit No. _____
 Basin 449 Elko Segment

WELL DRILLER'S REPORT
 Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 13152

1. OWNER Fidel VASQUEZ ADDRESS AT WELL LOCATION 3.55555 HAS BEEN RELOCATED
 MAILING ADDRESS 132 3rd Elko NV 89801

2. LOCATION SW 1/4 NW 1/4 Sec 35 T 34 N/S R. 55 G Elko County _____
 PERMIT NO. _____ Parcel No. lot 2 Blk 60 Subdivision Name Meadow Valley Ranches

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|--------------------|--------------|------|-----|------------|
| Loam | | 0 | 1 | |
| Gravel | | 1 | 18 | |
| Cemented sandstone | | 18 | 32 | |
| Clay | | 32 | 83 | |
| Hard red siltstone | | 83 | 136 | |
| Black sandstone | | 136 | 170 | |
| Brown sandstone | | 170 | 225 | |
| Sand & Gravel | Water | 225 | 300 | 25' |

8. WELL CONSTRUCTION

Diameter 10" inches Total depth 300 feet

Casing record 6 3/8" inches Thickness 203 inches

Weight per foot _____ Thickness _____

| Diameter | From | To |
|----------------------|--------------------|-----------------|
| <u>6 3/8"</u> inches | <u>7 1/2'</u> feet | <u>300</u> feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |

Surface seal: Yes No Type Grout

Depth of seal 51 feet

Gravel packed: Yes No

Gravel packed from 51 feet to 300 feet

Perforations:
 Type perforation slots
 Size perforation 3/16 - 3"
 From 260 feet to 300 feet
 From _____ feet to _____ feet

Date started _____, 1989
 Date completed _____, 1990

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|----------|--------|-----------|------------------|
| | | | |
| | | | |
| | | | |

BAILER TEST

G.P.M. 18 Draw down 3.2 feet 3 hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL

Static water level 108 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name AAA Drilling Co Contractor
 Address 355 West River Elko Contractor

Nevada contractor's license number issued by the State Contractor's Board 20684

Nevada contractor's driller's number issued by the Division of Water Resources 904

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584

Signed Shel C. Terry
 By driller performing actual drilling on site or contractor

Date 7-2-90

'90 JUL -5 AM 1:46
 '90 SEP 14 AM 10:03
 RECEIVED
 STATE ENGINEERS OFFICE