

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. None

PRINT OR TYPE ONLY

1. OWNER CURTIS WALKER ADDRESS AT WELL LOCATION N/A
 MAILING ADDRESS VALLEY VISTA ESTATES
ELKO, NV 89801

2. LOCATION SW 1/4, 30 1/4 Sec. 34 T. 34 N. S. R. 56 E. ELKO County
 PERMIT NO. _____ Lot 5 Blk B Subdivision Name VALLEY VISTA ESTATES
Issued by Water Resources Parcel No.

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|-------------------------------|-------------------------------------|------------|------------|------------|
| <u>Sandy loam</u> | | <u>0</u> | <u>12</u> | <u>12</u> |
| <u>Sand</u> | <input checked="" type="checkbox"/> | <u>12</u> | <u>14</u> | <u>2</u> |
| <u>Sandy clay</u> | | <u>14</u> | <u>92</u> | <u>78</u> |
| <u>sand (thin streak)</u> | <input checked="" type="checkbox"/> | | <u>92</u> | |
| <u>Sandy clay</u> | | <u>92</u> | <u>104</u> | <u>12</u> |
| <u>sand w/ clay interbeds</u> | <input checked="" type="checkbox"/> | <u>104</u> | <u>122</u> | <u>18</u> |
| <u>Clay</u> | | <u>122</u> | <u>128</u> | <u>6</u> |
| <u>T.D. 128</u> | | | | |

8. WELL CONSTRUCTION

Diameter 10.68 inches Total depth 128 feet
 _____ inches
 _____ inches

Casing record 1.31 ft x 1.88 & 2.19 steel casing
 Weight per foot _____ Thickness _____

| Diameter | From | To |
|--------------------|-----------------|-----------------|
| <u>6.78</u> inches | <u>4.3</u> feet | <u>128</u> feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |

Surface seal: Yes No Type cement/grout
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 128 feet

Perforations:
 Type perforation Torch cut
 Size perforation 1/2 x 3/8 x 4 ft
 From 102 feet to 123 feet
 From _____ feet to _____ feet

Date started 5/15 1990
 Date completed 5/10 1990

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|----------|--------|-----------|------------------|
| | | | |
| | | | |
| | | | |

BAILER TEST

G.P.M. 35.0 Draw down 0 feet 1 hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL

Static water level 12 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name MWA Drilling Co. Contractor
 Address 203 Pine St. Elko, NV 89801 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 10819
 Nevada contractor's driller's number issued by the Division of Water Resources 682
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 682
 Signed James V. Muth By driller performing actual drilling on site or contractor
 Date 5/19/90