

DCB

WELL DRILLER'S REPORT

PRINT OR TYPE ONLY Please complete this form in its entirety

1. OWNER HAROLD AND JACKIE ALLEN ADDRESS AT WELL LOCATION ARTHUR AVE  
DEW INC Between 5th & 6th STREET  
MAILING ADDRESS ELKO NV 89801 NO ADDRESS HAS BEEN ASSIGNED  
S<sup>2</sup>NW + SW + SE = DCB  
2. LOCATION S<sup>2</sup>NW 1/4 SW 5<sup>th</sup> Sec 36 T 36 N 8 R 56 E ELKO County  
PERMIT NO. [OLD APN = 006-33H-46] -46-1 APN = 006-33H-077 = 6226 ARTHUR AVE  
Issued by Water Resources Parcel No. Subdivision Name

NOTICE OF INTENT NO. 13184

3. TYPE OF WORK  
New Well  Recondition   
Deepen  Other

4. PROPOSED USE  
Domestic  Irrigation  Test   
Municipal  Industrial  Stock

5. TYPE WELL  
Cable  Rotary   
Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY Loam		0	4	4'
Light TAN CLAY		4	34	30'
SAND		34	37	3'
Light TAN CLAY		37	60	23'
GRAVEL		60	63	3'
Light TAN CLAY		63	118	55'
SAND & GRAVEL	water	118	127	9'

8. WELL CONSTRUCTION

Diameter 10 inches Total depth 127 feet

Casing record 6 5/8" STEEL

Weight per foot \_\_\_\_\_ Thickness 203

Diameter	From	To
<u>6 5/8" inches</u>	<u>± 1</u> feet	<u>127'</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type Cement

Depth of seal 51' feet

Gravel packed: Yes  No

Gravel packed from 51 feet to 127 feet

Perforations:  
Type perforation slots  
Size perforation 3/16 - 3"  
From 97 feet to 127 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

RECEIVED  
STATE ENGINEERS OFFICE  
NOV 5 1989

RECEIVED  
STATE ENGINEERS OFFICE  
NOV 19 1989

Date started \_\_\_\_\_, 1989  
Date completed \_\_\_\_\_, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>16-18</u>	<u>55</u>	<u>1 1/2</u>	
_____	_____	_____	_____
_____	_____	_____	_____

BAILER TEST

G.P.M. 16-18 Draw down 55 feet 1 1/2 hours  
G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL

Static water level 4.3' feet below land surface  
Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name AAA Drilling Co  
Address 355 West River St Elko

Nevada contractor's license number issued by the State Contractor's Board 20684

Nevada contractor's driller's number issued by the Division of Water Resources 904

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584

Signed Shovel C. Terry  
By driller performing actual drilling on site or contractor

Date 5-10-90