


OFFICE USE ONLY  
 Log No. 34357  
 Permit No. \_\_\_\_\_  
 Basin CI-44



**WELL DRILLER'S REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 121158

PRINT OR TYPE ONLY

1. OWNER Michael Brannin ADDRESS AT WELL LOCATION HAYES AVE  
 MAILING ADDRESS 1097 PANORAMA DR NEVADA ST & G STREET

2. LOCATION 1/2 SE 3/4 SE 3/4 Sec 36 T 36 @ S R. 56 E EIKO County  
 PERMIT NO. \_\_\_\_\_ Parcel No. Ryndon Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock  Other

5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Loam</u>		<u>0</u>	<u>3</u>	
<u>7IN Color Clay</u>		<u>3</u>	<u>58 1/2</u>	
<u>SAND Gravel</u>	<u>water</u>	<u>58 1/2</u>	<u>58 1/2</u>	
<u>CLAY</u>		<u>58 1/2</u>	<u>82</u>	
<u>Limestone</u>		<u>82</u>	<u>83</u>	
<u>Gravel</u>	<u>water</u>	<u>83</u>	<u>87</u>	
<u>CLAY</u>		<u>87</u>	<u>140</u>	
<u>SAND mid with Gravel</u>	<u>water</u>	<u>140</u>	<u>160</u>	

8. WELL CONSTRUCTION  
 Diameter 6 3/8 inches Total depth 160 feet  
 \_\_\_\_\_ inches  
 \_\_\_\_\_ inches  
 Casing record 6 3/8 188 WALL STEEL  
 Weight per foot \_\_\_\_\_ Thickness 188  
 Diameter From To  
6 inches +1 feet 160 feet  
 \_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet

Surface seal: Yes  No  Type Grout  
 Depth of seal 51 feet  
 Gravel packed: Yes  No   
 Gravel packed from 51 feet to 160 feet

Perforations:  
 Type perforation slots  
 Size perforation \_\_\_\_\_  
 From 120 feet to 160 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

'90 SEP 14 AM 10:03  
 RECEIVED  
 STATE ENGINEERS OFFICE

Date started 4-30, 1990  
 Date completed 5-2, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST  
 G.P.M. 62 Draw down 27 feet 3 hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL  
 Static water level 62' feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Good °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name AAA Drilling Co Contractor  
 Address 355 West River EIKO Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 20684  
 Nevada contractor's driller's number issued by the Division of Water Resources 904  
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 1584  
 Signed Shoel C. Petty &  
 By driller performing actual drilling on site or contractor  
 Date 7-4-90