

*SECTION 31000 I* WELL DRILLER'S REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 13026

1. OWNER Brad Keife ADDRESS AT WELL LOCATION 2985 Lakeshore Dr  
MAILING ADDRESS 20980 Ames Ln Lot 2 / New Washoe City  
Reno, Nv 89511 County Washoe  
2. LOCATION SW 1/4 SW 1/4 Sec. 31 T. 17 N/S R. 20 E County  
PERMIT NO. 50-340-02 Subdivision Name Lakeshore Farms  
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
New Well  Recondition   
Deepen  Other

4. PROPOSED USE  
Domestic  Irrigation  Test   
Municipal  Industrial  Stock

5. TYPE WELL  
Cable  Rotary   
Other  Mud

6. LITHOLOGIC LOG

| Material  | Water Strata | From | To  | Thick-ness |
|---|--------------|------|-----|------------|
| Brown sandy soil  |              | 0    | 2   | 2          |
| Multi-colored sand  |              | 2    | 18  | 16         |
| Dark green clay & fine sand                                       |              | 18   | 37  | 19         |
| Dark & Light green clay [Sticky] with some multi-colored sands    |              | 37   | 127 | 90         |
| White green blue black brown coarse sand with traces of blue clay |              | 127  | 144 | 17         |
| White green black coarse sand with fine sand                      |              | 144  | 190 | 46         |
| White green black coarse sand with fine sand & traces brown clay  |              | 190  | 227 | 37         |
| Brown clay & fine sand  |              | 227  | 229 | 2          |
| T.D. 229  |              |      |     |            |

8. WELL CONSTRUCTION  
Diameter 13 inches Total depth 229 feet  
Casing record 8 5/8 inch  
Weight per foot 16.96 Thickness .188  
Diameter 8 5/8 inches From + 1 feet To 229 feet  
Surface seal: Yes  No  Type neat cement  
Depth of seal 130 feet  
Gravel packed: Yes  No   
Gravel packed from 130 feet to 229 feet  
Perforations:  
Type perforation screen  
Size perforation .030  
From 139 feet to 159 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 5/2/90  
Date completed 5/4/90

7. WELL TEST DATA

| Pump RPM   | G.P.M.     | Draw Down   | After Hours Pump |
|--|------------|-------------|------------------|
| <u>90</u>  | <u>20+</u> | <u>STAT</u> | <u>STAT</u>      |
| <u>Blew with air to clean and develop 7 hrs.</u> |            |             |                  |

BAILER TEST  
G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL  
Static water level 5 feet below land surface  
Flow 20+ G.P.M. P.S.I.  
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Aqua Drilling & Well Service, Inc.  
Address 625 Spice Islands Dr Suite L Sparks, Nv 89431  
Nevada contractor's license number issued by the State Contractor's Board 15291  
Nevada contractor's driller's number issued by the Division of Water Resources 1132  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1509  
Signed Roger M. Thrall  
By Driller performing actual drilling on site or contractor  
Date 5/7/90