WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 34369
Permit No.
Basin 8-104

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 13969

1. OWNER Alan Rushing
MAILING ADDRESS P.O. Box 1736
Carson City, NV 89702

ADDRESS AT WELL LOCATION ~~9360~~ 5300 Kings Canyon Rd.
Carson City, NV 89702

2. LOCATION SE ¼ SE ¼ Sec. 22 T. 15 (N/S) R. 19 E. Carson City County
PERMIT NO. N/A (Issued by Water Resources) 7-06-41 (Parcel No.) none (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Frac. Rock & Dirt		0	7	
Hard Granite		7	22	
Broken Granite		22	34	
White Granite		34	115	
Brown Shist		115	175	
Brown Sandstone		175	185	
Grey Sandstone		185	210	
Granite		210	265	
Fractured Granite	x	265	270	
Solid Granite		270	310	
Fractured Granite		310	318	
Solid Granite		318	335	
Fractured Granite	xx	335	365	

N39.144141
W119.829557
NAD83

90 AUG 24 AM 10:33
RECEIVED
STATE ENGINEER

Date started 7/19/90, 19
Date completed 7/31/90, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

~~BAILER~~ air TEST
G.P.M. 20 (Approx.) Draw down 365 feet 4 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter 12 inches Total depth 11 feet
10 inches 50
8 3/4 inches 365'
Casing record Steel
Weight per foot Thickness .156

Diameter	From	To
6 inches	-1 feet	365 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Concrete
Depth of seal 50+ feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 365' feet

Perforations:
Type perforation Holte Perforator
Size perforation 1"x¼"
From 260 feet to 360 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 290' feet below land surface
Flow none G.P.M. none P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Drilling Research Inc. (Contractor)
Address P.O.Box 8056 Reno, NV 89507 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0027791-C23
Nevada contractor's driller's number issued by the Division of Water Resources 873
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1533
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 8-21-90

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627