

OFFICE USE ONLY
 Log No. 34379
 Permit No. _____
 Basin 8-105

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 13714

PRINT OR TYPE ONLY

1. OWNER ROY PARODI ADDRESS AT WELL LOCATION 1068 LOG CABIN RD.
 MAILING ADDRESS 1068 LOG CABIN RD. GARDNERVILLE, NV
GARDNERVILLE, NV 12 12 NS R. 20 E DOUGLAS County
 2. LOCATION NE 1/4 SE 1/4 Sec. 23 T. 12 N. R. 20 E DOUGLAS
 PERMIT NO. 23-234-04 SAGEWOOD ESTATES, 1073 CORTEZ LANE
 Issued by Water Resources Parcel No. (new app # 1220-12-710-015) Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY CLAY w/ GRAVEL		0'	125'	125'
CLAY		125'	165'	40'
SANDY CLAY		165'	195'	30'
SANDY CLAY w/ GRAVEL	✓	195'	230'	35'
CLAY		230'	260'	30'
SANDY CLAY w/ GRAVEL	✓	260'	300'	40'

23-234-040 corner lot is at 1070 Cortez Ln legal is NE SE 1/4 12 N 20 E
 NEW APP # 1220-12-710-015
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION
 Diameter 6 3/8 inches Total depth 300 feet
 Casing record STEEL
 Weight per foot 17 Thickness .188"

Diameter	From	To
<u>6 3/8</u> inches	<u>0</u> feet	<u>300</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type CEMENT GROUT
 Depth of seal 53 feet
 Gravel packed: Yes No
 Gravel packed from 53 feet to 300 feet

Perforations:
 Type perforation SINGLE FACTORY
 Size perforation 1/8" x 3"

From	feet to	feet
<u>220</u>	<u>240</u>	feet
<u>280</u>	<u>300</u>	feet
_____	_____	feet
_____	_____	feet
_____	_____	feet

Date started 9-28 1990
 Date completed 10-5 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>AIR TEST</u>	<u>20+</u>		

BAILER TEST

G.P.M.	Draw down	feet	hours

9. WATER LEVEL
 Static water level 200 feet below land surface
 Flow 20+ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name W. E. HOGGARD, JR. (EDDCO) Contractor
 Address 7780 CURRY RD., FALLON, NV Contractor
 Nevada contractor's license number issued by the State Contractor's Board 27673
 Nevada contractor's driller's number issued by the Division of Water Resources #1586
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller #1586T-1
 Signed Pat F. Moore By driller performing actual drilling on site or contractor
 Date 10-8-90