

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 114510

PRINT OR TYPE ONLY

1. OWNER Don Keagy ADDRESS AT WELL LOCATION 205 Trail Court  
MAILING ADDRESS 205 Trail Court Genoa, NV  
Genoa, NV

2. LOCATION SW 1/4 SW 1/4 Sec 3 T 13 Q/S R 19 E Douglas County  
PERMIT NO. 17-072-11 Genoa Subdivision Name  
Issued by Water Resources Parcel No.

3. TYPE OF WORK  
New Well  Recondition   
Deepen  Other

4. PROPOSED USE  
Domestic  Irrigation  Test   
Municipal  Industrial  Stock

5. TYPE WELL  
Cable  Rotary   
Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Overburden with fine sand and talus rock, hard		0	9	9
Loose, hard talus rock, very abrasive, with boulders, hard, water course at 87' @ 3 gpm	x	9	131	122
Hard, fractured granite	x	131	160	29
Major water courses between 149 and 155'				
TD at 160 ft				

90 SEP 18 AM 10:16 RECEIVED STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION

Diameter 11 1/2 to 60' inches Total depth 160 feet  
9 1/2 inches  
Casing record Steel 6 5/8"  
Weight per foot 13.03 Thickness .188

Diameter	From	To
<u>6 5/8</u> inches	<u>2</u> feet	<u>160</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type Concrete  
Depth of seal 57 feet  
Gravel packed: Yes  No   
Gravel packed from 57 feet to 160 feet

Perforations:  
Type perforation Factory mill slotted  
Size perforation 3" x 3/32"  
From 140 feet to 160 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started Sept 10, 1990  
Date completed Sept 13, 1990

9. WATER LEVEL  
Static water level 87 feet below land surface  
Flow 18-20 G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature Cold °F Quality Good

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Flushed with clear water to remove drilling mud and to gravel pack with pea gravel.			
Developed well with 250-450 air for three hours. Blowing gpm from _____			

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name A & H PUMP CO. Contractor  
Address CARSON CITY, NV 89701 Contractor  
Nevada contractor's license number issued by the State Contractor's Board 23295  
Nevada contractor's driller's number issued by the Division of Water Resources \_\_\_\_\_  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1674  
Signed [Signature] By driller performing actual drilling on site or contractor  
Date Sept 14/1990

BAILER TEST

G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours