

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 11503

1. OWNER PAINTER CONSTRUCTION ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS Box 37 1583 Orchard  
GENOA, NEVADA Gardnerville, Nevada 89410  
 2. LOCATION NE  $\frac{1}{4}$  NE  $\frac{1}{4}$  Sec. 34 T. 13 Q/S R. 20 E. Douglas County  
 PERMIT NO. 23-260-07 Parcel No. None Subdivision Name \_\_\_\_\_  
Issued by Water Resources

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other  Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Overburden		0	3	3
Gravels, loose to semi hard, with fine sand		3	40	37
Clays with imbedded gravels and sand		40	90	50
Gravel with fine to course sand, interspersed with clay lenses	xx	90	140	50
TD 140'				

190 OCT -5 A 8:49  
STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION  
 Diameter 11 3/4 inches Total depth 140 feet  
 Casing record Steel 6 5/8"  
 Weight per foot 13.03 Thickness .188

Diameter	From	To
<u>6 5/8</u> inches	<u>1 2</u> feet	<u>140</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type Concrete  
 Depth of seal 105 feet  
 Gravel packed: Yes  No   
 Gravel packed from 105 feet to 140 feet

Perforations:  
 Type perforation Factory Mill Slotted  
 Size perforation 3" x 3/32"  
 From 120 feet to 140 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started Sept. 26, 1990  
 Date completed Sept. 28, 1990

9. WATER LEVEL  
 Static water level 37 feet below land surface  
 Flow 30 plus G.P.M. P.S.I. \_\_\_\_\_  
 Water temperature cool °F Quality good

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Flushed mud from well and gravel packed to 105 feet. Developed well with air and blew 30 plus gpm from 110 feet to clean well. Blew well for 3 hours			

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name A & H PUMP CO. Contractor  
 Address CARSON CITY, NEVADA Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 23295  
 Nevada contractor's driller's number issued by the Division of Water Resources \_\_\_\_\_  
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 1674  
 Signed [Signature]  
By driller performing actual drilling on site or contractor  
 Date 9/28/90

BAILER TEST

G.P.M.	Draw down	feet	hours
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____