WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 34395
Permit No.
Basin 6-89

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 14514

1. OWNER DON BAULMER
MAILING ADDRESS 5678 OLD HWY 395
WASHOE, NV

ADDRESS AT WELL LOCATION 5678 OLD HWY 395
WASHOE, NV

2. LOCATION SW ¼ NW ¼ Sec. 14 T. 16 N/S R. 19 E. WASHOE County
PERMIT NO. ~~WASHOE 3897~~ (Issued by Water Resources) 55-162-05 (Parcel No.) Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| SAND | | 0' | 2' | 2' |
| DG, SAND, CLAY | | 2' | 135' | 133' |
| DG, SAND | X | 135' | 150' | 15' |

'90 OCT -2 A10:17
RECEIVED
STATE ENGINEER'S OFFICE

Date started 9-24, 1990
Date completed 9-25, 1990

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| AIR TEST | 25 + | | |

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 6 3/8 inches Total depth 150 feet
..... inches
..... inches
Casing record
Weight per foot ..... Thickness .188"

| Diameter | From | To |
|---|---|---|
| 6 3/8 inches | 0 feet | 150 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☒ No ☐ Type CEMENT GROUT
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 150 feet to 50 feet

Perforations:
Type perforation SINGLE FACTORY
Size perforation 1/8" X 4"
From 150 feet to 130 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 53 feet below land surface
Flow 25 + G.P.M. ..... P.S.I.
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name W. E. HOGGARD (Contractor)
Address 7780 CURRY RD., FALLON, NV (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 27673
Nevada contractor's driller's number issued by the Division of Water Resources #1586
Nevada driller's license number issued by the Division of Water Resources, the on-site driller #1586T-1
Signed Patt J. Moore (By driller performing actual drilling on site or contractor)
Date 9-26-90

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627