

OFFICE USE ONLY
 Log No. 34415
 Permit No. _____
 Basin 6-91

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 14639

PRINT OR TYPE ONLY

1. OWNER Brad and Linda Scott ADDRESS AT WELL LOCATION 13 Mountain Ridge Road
 MAILING ADDRESS 1985 Coleman
Reno, Nv 89503

2. LOCATION SW $\frac{1}{4}$ NE $\frac{1}{4}$ Sec 10 T. 19 N/S R. 18 E Washoe County
 PERMIT NO. 38-370-01 - Mogul

Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay top soil		0	2	2
Sandy decomposed granite		2	35	33
Green fractured granite		35	65	30
More fractured granite	X	65	90	25
Soft granite less fractured	XX	90	155	65
Blue clay/ rock layered		155	165	10
Semi hard granite rock		165	238	73
T.D. 238 ft.				

90 OCT 9 11:00 AM '90 STATE ENGINEERS OF NEVADA

8. WELL CONSTRUCTION

Diameter _____ inches Total depth 238 feet
 _____ inches
 _____ inches

Casing record 6 5/8 inch
 Weight per foot _____ Thickness .156

Diameter	From	To
<u>6 5/8</u> inches	<u>+1</u> feet	<u>238</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type concrete
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 238 feet

Perforations:
 Type perforation factory
 Size perforation 3/ 32 X 3
 From 100 feet to 120 feet
 From 160 feet to 180 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Date started 9/12/90, 19____
 Date completed 9/14/90, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew with air to clean and develop.			

BAILER TEST

G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours

9. WATER LEVEL

Static water level 90 feet below land surface
 Flow 20+ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling & Well Service, Inc
 Address 625 Spice Islands Dr Suite L Sparks
 Contractor 89431

Nevada contractor's license number 15291
 issued by the State Contractor's Board

Nevada contractor's driller's number 1132
 issued by the Division of Water Resources

Nevada driller's license number issued by the 1533
 Division of Water Resources, the on-site driller

Signed Roger M. Thrall
 By driller performing actual drilling on site or contractor

Date Roger M. Thrall 9/14/90