

OFFICE USE ONLY
 Log No. 34247
 Permit No. 2-87
 Basin 2-87
 NOTICE OF INTENT NO. 13012

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

1. OWNER Manuel Wedge ADDRESS AT WELL LOCATION 2665 Westview
 MAILING ADDRESS 2665 Westview 2665 Westview
Sparks, Nv 89434 Lot 8
 2. LOCATION NW 1/4 NW 1/4 Sec 1 T. 19 N/S R. 20 E. Washoe County
 PERMIT NO. 30-181-05 - Sunset View Rancho Estates
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Black volcanic rock w/traces brown & green volcanic rock		180	213	33
Green, black, red volcanic rock		213	265	52
Reddish, brown black gray volcanic rock		265	296	31
Gray white blk green red volcanic rock w/traces hard brown clay		296	367	71
Multi-colored volcanic rock		367	461	94
Multi-colored volcanic rock broken	X	461	565	104
Blue yellow hard clay w/some multi colored volcanic rock		565	640	75
T.D. 640 feet				

8. WELL CONSTRUCTION
 Diameter 6 1/8 inches Total depth 640 feet
 Casing record 5 inch
 Weight per foot 9.66 Thickness .188
 Diameter 5 inches From 160 feet To 640 feet
 Surface seal: Yes No Type _____
 Depth of seal Please refer to original log feet
 Gravel packed: Yes No as per Tom Gallagher 10/9
 Gravel packed from _____ feet to _____ feet
 Perforations:
 Type perforation factory
 Size perforation 3/32 X 3
 From 520 feet to 540 feet
 From 600 feet to 620 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Date started 7/30/90 19_____
 Date completed 8/8/90 19_____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew with air to clean and develop.			

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL
 Static water level 500 feet below land surface
 Flow 2 G.P.M. P.S.I.
 Water temperature cold °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling & Well Service, Inc
 Address 625 Spice Islands Dr Sutie L Sparks 89431
 Nevada contractor's license number 15291
 issued by the State Contractor's Board
 Nevada contractor's driller's number 1132
 issued by the Division of Water Resources
 Nevada driller's license number issued by the 1509
 Division of Water Resources the on-site driller
 Signed Roger M. Thrall
 By driller performing actual drilling on site or contractor
 Date Roger M. Thrall 8/10/90