WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 34418
Permit No. 55207-T
Basin 6-8E

PRINT OR TYPE ONLY

plugged under NOI 61177

NOTICE OF INTENT NO. 113571

1. OWNER City of Sparks
MAILING ADDRESS 431 Prater Way Sparks NV 89431

ADDRESS AT WELL LOCATION Willow Creek Station Park 2100 E Prater Way

2. LOCATION SW ¼ NE ¼ Sec. 3 T. 19 N/S R. 20 E. Washoe County
PERMIT NO. 55207 - T/58439 (Issued by Water Resources) 36-411-07 (Parcel No.) N39.542262 W119.723315 NAD27 (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☒ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fill		0	5	5
sd		5	10	5
gravel		10	14	4
Brn clay		14	22	8
Large gravel		22	50	28
Clay + sd.		50	53	3
Large gravel		53	65	12
cl		65	70	5
gravel	✓	70	74	4
Clay + sd	✓	74	100	26
gr. cl.		100	125	25
gravel	✓	125	130	5
gr. cl.		130	145	15
gravel	✓	145	149	4
gr. cl.		149	210	61
sdy cly (Rust Color)	✓	210	215	5
grey clay		215	217	2
gr. clay		217	235	18
sd		235	240	5
gr. cl.		240	270	30
gravel + sd	✓	270	275	5
clay		275	290	15

RECEIVED SEP 18 1990 STATE ENGINEER'S OFFICE

Date started 8-27, 1990
Date completed 9-3, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Air Lift			

BAILER TEST
G.P.M. Air Lift Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours

8. WELL CONSTRUCTION
Diameter 14¾ inches Total depth 290 feet
____ inches
____ inches
Casing record 8 5/8 + 0-290
Weight per foot 22.36 Thickness .250

Diameter	From	To
8 inches	+1 feet	290 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Neat Cement
Depth of seal 52 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 52 feet to 290 feet

Perforations:
Type perforation Milled slot
Size perforation ⅛" X 3"
From 60 feet to 100 feet
From 140 feet to 160 feet
From 220 feet to 240 feet
From 260 feet to 280 feet
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 25 feet below land surface
Flow 200 + G.P.M. ____ P.S.I.
Water temperature C °F Quality good - silty

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Woytek Drilling Co (Contractor)
Address 4662 Maynard Sparks NV 89433 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 24521
Nevada contractor's driller's number issued by the Division of Water Resources 1374
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1442
Signed Leo Woytek (By driller performing actual drilling on site or contractor)
Date 9-6-90

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627