

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 14542

1. OWNER Arco Products, Inc. ADDRESS AT WELL LOCATION AM-PM Mart at corner of Rock Blvd. and B. St. in Sparks NV.
 MAILING ADDRESS P.O. Box 58011 San Mateo Ca. 94402 MW-2

2. LOCATION SE 1/4 SW 1/4 Sec 5 T. 19 N S R 20 E Washoe County
 PERMIT NO. MO-281 Issued by Water Resources Parcel No. None Subdivision Name None

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Silty Sand with 1' of asphalt on top</u>		<u>0</u>	<u>5</u>	<u>5</u>
<u>Sand</u>		<u>5</u>	<u>10</u>	<u>5</u>
<u>gravelly sand</u>		<u>10</u>	<u>15</u>	<u>5</u>
<u>sandy gravel</u>		<u>15</u>	<u>20</u>	<u>5</u>
<u>sand, gravel and cobble</u>		<u>20</u>	<u>25</u>	<u>5</u>
		<u>39</u>	<u>25</u>	<u>4</u>

'90 SEP 27 AND 34
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION

Diameter 9 inches Total depth 39 feet

Casing record Schedule 40 PVC-Threaded
 Weight per foot NA Thickness Sched 40

Diameter	From	To
<u>4</u> inches	<u>0</u> feet	<u>38</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type Cement
 Depth of seal 10 feet
 Gravel packed: Yes No
 Gravel packed from 12 feet to 39 feet

Perforations:
 Type perforation slot
 Size perforation .02
 From 13 feet to 38 feet
 From _____ feet to _____ feet

Date started 8-28, 1990
 Date completed 8-28, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>NA</u>	<u>NA</u>	<u>NA</u>	<u>NA</u>
_____	_____	_____	_____
_____	_____	_____	_____

BAILER TEST

G.P.M. NA Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL

Static water level 21 feet below land surface
 Flow None G.P.M. None P.S.I.
 Water temperature None °F Quality None

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Becker Drills Inc. Contractor
 Address 11465 N. Hwy 2 Box 567 Commerce City Co. Contractor
 Nevada contractor's license number issued by the State Contractor's Board 0010071
 Nevada contractor's driller's number issued by the Division of Water Resources 29577
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1563
 Signed Steve A. Syby
 By driller performing actual drilling on site or contractor
 Date 8-28-90