



**WELL DRILLER'S REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 14781

1. OWNER JOE & SHARON LANE ADDRESS AT WELL LOCATION Same  
 MAILING ADDRESS 7675 Tamra  
Reno, NV 89506  
 2. LOCATION SW 1/4 SE 1/4 Sec 3 T. 20N N/S R. 19 E Washoe County  
 PERMIT NO. 88-082-18 Parcel No. Golden Valley Subdivision Name HMH #1 lot 10  
 Issued by Water Resources

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other  Air

6. LITHOLOGIC LOG

| Material          | Water Strata | From | To  | Thick-ness |
|-------------------|--------------|------|-----|------------|
| WELL DEEPENING    |              |      |     |            |
| Fill              |              | 230  | 240 | 10         |
| Gray hard granite |              | 240  | 269 | 29         |
| Fracture          | X            | 269  | 270 | 1          |
| Gray hard granite |              | 270  | 289 | 19         |
| Fracture          | X            | 289  | 290 | 1          |
| Gray hard granite |              | 290  | 300 | 10         |

90 SEP 17 AM 124  
 RECEIVED  
 STATE ENGINEERS OFFICE

Original Completion log # 10722

8. WELL CONSTRUCTION  
 Diameter 6 1/8 inches Total depth 300 feet  
 Casing record 80' of steel liner installed to 300'  
 Weight per foot 134 Thickness 134  
 Diameter From To  
5"OD inches 220 feet 300 feet  
 Surface seal: Yes  No  Type N/A  
 Depth of seal          feet  
 Gravel packed: Yes  No  extension in hard granite  
 Gravel packed from          feet to          feet

Perforations:  
 Type perforation factory sawed slot  
 Size perforation 3/32 x 3 x 5 around  
 From 220 feet to 240 feet  
 From 260 feet to 300 feet  
 From          feet to          feet  
 From          feet to          feet  
 From          feet to          feet

Date started 9-13-90, 1990  
 Date completed 9-13-90, 1990

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|----------|--------|-----------|------------------|
|          |        |           |                  |
|          |        |           |                  |
|          |        |           |                  |

BAILER TEST

G.P.M.          Draw down          feet          hours  
 G.P.M.          Draw down          feet          hours  
 G.P.M.          Draw down          feet          hours

9. WATER LEVEL  
 Static water level 235 feet below land surface  
 Flow 15 G.P.M. P.S.I.           
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Wayne Drilling, Inc. Contractor  
 Address P.O. Box 12370 Reno, NV 89510 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 22549  
 Nevada contractor's driller's number issued by the Division of Water Resources 908  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923  
 Signed Edward J. Brondage  
 By driller performing actual drilling on site or contractor  
 Date September 14, 1990