WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 34433
Permit No.
Basin 7-02a

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 11352

1. OWNER Pava Construction
MAILING ADDRESS 2595 Coppa Way
Sparks Nv 89431

ADDRESS AT WELL LOCATION 10120 Blackhawk Dr.
Reno, Nv.

2. LOCATION NE ¼ NE ¼ Sec. 24 T. 21 N/S R. 18 E. Washoe County
PERMIT NO. (Issued by Water Resources) 86-23209 (Parcel No.) (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	12	
Friable Granite wash		12	30	
Clay		30	50	
gravel		50	54	
Sdy clay		54	65	
gravel		65	67	
clay		67	71	
gravel		71	77	
clay		77	83	
gravel	—	83	85	
clay		85	87	
gravel		87	88	
clay		88	100	
gravel		100	104	
clay		104	109	
gravel w/clay		109	122	
white quartz gravel		122	130	
gravel & clay		130	136	
Sd.		136	137	
gravel		137	148	
gravel & clay		148	160	
gravel & sd		160	170	
clay		170	190	
gravel	—	190	193	
clay + gravel		193	197	
Sdy clay		197	210	

Date started 9-11, 1990
Date completed 9-14, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	N/A		
	Air Lift		

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Air Lift Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter 11 inches Total depth 210 feet
inches
inches
Casing record 6 5/8 X .188 +1 - 210'
Weight per foot 12.81 Thickness .188

Diameter	From	To
6 inches	+1 feet	210 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Neat Cement
Depth of seal 52 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 52 feet to 210 feet

Perforations:
Type perforation Milled
Size perforation 1/8" X 2 1/2
From 180 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 85 feet below land surface
Flow 60 G.P.M. P.S.I.
Water temperature C °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Waytek Drilling Co (Contractor)
Address 4662 Maynard Sparks, Nv. (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 24521
Nevada contractor's driller's number issued by the Division of Water Resources 1374
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1374
Signed Lee Waytek (By driller performing actual drilling on site or contractor)
Date 9-18-90

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627