

OFFICE USE ONLY
 Log No. 34436
 Permit No. _____
 Basin 684

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 14774

PRINT OR TYPE ONLY

1. OWNER ROBERT KELLY ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 15555 Pyramid Hwy. 15555 (Pyramid Hwy) SR 445
Reno, NV 89510 Reno, NV 89510
 2. LOCATION NW 1/4 SE 1/4 Sec. 12 T. 22N N/S R. 20 E Washoe County
 PERMIT NO. 076-252-024 Palomino Valley 2.15 12.2.8.2
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	2	2
Soft brown sand		2	10	8
Brown clay with DG		10	30	20
Green weatheerd granite		30	63	33
Gray hard granite		63	152	89
Soft zone (app 5 GPM)	X	152	171	19
Gray hard granite		171	198	27
Soft zone (app 2 GPM)	X	198	203	5
Softer gray granite		203	231	28
Soft zone (app 3 GPM)	X	231	238	7
Gray granite		238	250	12

90 SEP 17 AM 12:24
 STATE ENGINEER OF NV

8. WELL CONSTRUCTION
 Diameter 8 5/8 inches Total depth 250 feet
10 inches 0 to 50 ft.
 inches
 Casing record: 250 ft steel casing installed.
 Weight per foot _____ thickness 156

Diameter	From	To
<u>6 5/8</u> inches	<u>0</u> feet	<u>250</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type cement grout
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 250 feet
 Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32x 3 x 5 around
 From 155 feet to 175 feet
 From 195 feet to 205 feet
 From 225 feet to 245 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Date started 9-10-90, 19____
 Date completed 9-12-90, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

9. WATER LEVEL
 Static water level 40 feet below land surface
 Flow 10 G.P.M. P.S.I. _____
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling, Inc.
Contractor
 Address P.O. Box 12370, Reno, NV 89510
Contractor
 Nevada contractor's license number issued by the State Contractor's Board 22549
 Nevada contractor's driller's number issued by the Division of Water Resources 908
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
 Signed Edward J. Landry
By driller performing actual drilling on site or contractor
 Date September 13, 1990

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours