WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 34442
Permit No.
Basin 4-48

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 15247

1. OWNER FRANCES LEW
MAILING ADDRESS P.O. Box 890
Elko, NV 89801

ADDRESS AT WELL LOCATION Intersection of Hilltop Drive & Emigrant trail

2. LOCATION SW ¼ NE ¼ Sec 14 T 33 N/S R 55 E County
PERMIT NO. (Issued by Water Resources) 77-002-01-2 (Parcel No.) Western Hills-Lot 1 Blk 2 (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand, gravel, & br. clay		0	20	20
Gray siltstone some gravel		20	100	80
Silicified material all colors		100	200	100
Volcanics (red, black)		200	500	300
Siltstone & bl. volcanics		500	700	200

'90 SEP 28 AM 10:42
STATE ENGINEER

Date started August 20, 1990
Date completed September 6, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blow test	7.5		

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 10 5/8 inches Total depth 700 feet
..... inches
..... inches
Casing record steel
Weight per foot ..... Thickness .188

Diameter	From	To
6 5/8 inches	+1 feet	700 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement
Depth of seal 0-50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 700 feet

Perforations:
Type perforation mill slot
Size perforation 1/8 x 2½
From 640 feet to 680 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 490 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature C °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING, INC. (Contractor)
Address P.O. Box 850 Elko, NV 89801 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada contractor's driller's number issued by the Division of Water Resources 1166
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1689
Signed David Hackworth (By driller performing actual drilling on site or contractor)
Date 27-8-1990

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627