

OFFICE USE ONLY
 Log No. 34443
 Permit No. 55100
 Basin 2-28
 NOTICE OF INTENT NO. 11350

WELL DRILLER'S REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

1. OWNER Lack Minerals ADDRESS AT WELL LOCATION 61 mi. N. of Lovelock on Lovelock - Sulphur Road, mining project
 MAILING ADDRESS SPARKS NV. Pershing County

2. LOCATION NE 1/4 NW 1/4 Sec. 19 T. 34 N. R. 30 E.
 PERMIT NO. 55100 W-MM79 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock Other

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown silty clay		0	17	17
yellow clay		17	85	68
Whit. & yellow clay 85	✓	85	165	80
green clay		165	270	105
Whit. chalky clay	✓	270	300	30

8. WELL CONSTRUCTION

Diameter 10 inches Total depth 300 feet
8 3/4 inches
 inches

Casing record.....
 Weight per foot 12.81 Thickness 1.88

Diameter	From	To
<u>6</u> inches	<u>+1</u> feet	<u>300</u> feet
..... inches feet feet
..... inches feet feet
..... inches feet feet
..... inches feet feet
..... inches feet feet

Surface seal: Yes No Type Mast Cement
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from..... feet to..... feet

Perforations:
 Type perforation milled slot
 Size perforation 1/8" x 3"

From	feet to	
<u>140</u>	<u>160</u>	feet
<u>180</u>	<u>190</u>	feet
<u>210</u>	<u>220</u>	feet
<u>240</u>	<u>250</u>	feet
<u>270</u>	<u>280</u>	feet

Date started 8-17, 1990
 Date completed 8-20, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

Air lift

BAILER TEST

G.P.M. Air lift Draw down..... feet hours
 G.P.M. Draw down..... feet hours
 G.P.M. Draw down..... feet hours

9. WATER LEVEL

Static water level 120 feet below land surface
 Flow 20 G.P.M. P.S.I.
 Water temperature C °F Quality Milky

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Woytek Drilling Co Contractor
 Address 4662 Maynard Sparks NV 89433 Contractor

Nevada contractor's license number issued by the State Contractor's Board 24521
 Nevada contractor's driller's number issued by the Division of Water Resources 1374
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1442
 Signed Steve Woytek By driller performing actual drilling on site or contractor
 Date 9-5-90