WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 34458
Permit No.
Basin 4-419

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 15248

1. OWNER Adobe Heights, Inc.
MAILING ADDRESS P.O. Box 430
Elko, NV 89801

ADDRESS AT WELL LOCATION None

2. LOCATION SW ¼ NW ¼ Sec. 1 T 34 N/S R. 54 E Elko County
PERMIT NO. Waiver W 327 (Issued by Water Resources) | UNK (Parcel No.) | Adobe Heights (Subdivision Name)

3. TYPE OF WORK
New Well ☐ Recondition ☐
Deepen ☐ Other ☒

4. PROPOSED USE Exploratory
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	2	2
Dirt some rock		2	10	8
Gravel & clay		10	20	10
Dark gray shale		20	40	20
Light gray shale		40	60	20
Brown shale		60	85	25
Dark gray shale		85	115	30
Gray shale		115	400	185
Dark gray shale		400	410	10
Gray shale		410	600	190
Gray shale some quartz		600	660	60

RECEIVED OCT 4 90 NO:18 STATE ENGINEERS OFFICE

Date started September 10, 19 90
Date completed September 21, 19 90

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blow test	10		

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 10 5/8 inches Total depth 660 feet
..... inches
..... inches
Casing record steel
Weight per foot ..... Thickness .188

Diameter	From	To
6 5/8 inches	+2 feet	660 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement
Depth of seal ..... feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 100 feet to 660 feet

Perforations:
Type perforation Mill slot
Size perforation 1/8 x 2½
From 600 feet to 640 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 220 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature W °F Quality .....

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Hackworth Drilling, Inc. (Contractor)
Address P.O. Box 850 Elko, NV 89801 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada contractor's driller's number issued by the Division of Water Resources 1166
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1689
Signed David Hersh (By driller performing actual drilling on site or contractor)
Date 10-2-1990

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627