

WELL DRILLERS REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 12365

PRINT OR TYPE ONLY

OWNER Wallace Bird ADDRESS AT WELL LOCATION 50 mile N. of
 MAILING ADDRESS Box 626 Tonapah, NV
Tonapah, Nevada 89049
 2. LOCATION NW 1/4 NE 1/4 Sec. T 9 S R. 40 E Nye County
 PERMIT NO. -- Issued by Water Resources Parcel No. -- Subdivision Name --

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock Other
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|--------------------------|--------------|------|-----|------------|
| Top soil & sand | | 0 | 10 | 10 |
| Boulders lost circ. | | 10 | 12 | 2 |
| Volcanics fractured | | 12 | 25 | 13 |
| " dry | | 25 | 126 | 101 |
| " & clay | | 126 | 175 | 49 |
| " " | | 175 | 185 | 10 |
| Hard purple rock | | 185 | 205 | 20 |
| Clay | | 205 | 210 | 5 |
| Hard volcanics fractured | | 210 | 215 | 5 |
| Rusty rock | water | 215 | 225 | 10 |
| Drilling breaks | " | 225 | 227 | 2 |
| Hard & fractured | | 227 | 230 | 3 |
| Rusty rock | | 230 | 235 | 5 |
| Solid rock | T.D. | 235 | 250 | 15 |

8. WELL CONSTRUCTION
 Diameter hole 10 3/4 inches Total depth 250 feet
 Casing record 1/4 inch
 Weight per foot _____ Thickness 250 feet

| Diameter | From | To |
|-----------------|---------------|-----------------|
| <u>6</u> inches | <u>1</u> feet | <u>250</u> feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |

 Surface seal: Yes No Type Neet cement
 Depth of seal 100 feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet
 Perforations:
 Type perforation sawed
 Size perforation 1/8 X 2 1/2"
 From 170 feet to 250 feet
 From _____ feet to _____ feet

'90 AUG -6 AM 12:28
 STATE ENGINEERS

9. WATER LEVEL
 Static water level 12 feet below land surface
 Flow -- G.P.M. -- P.S.I.
 Water temperature cold F. Quality good

Date started May 25, 1990
 Date completed July 5, 1990

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|-------------------|----------------|---------------|------------------|
| <u>Air lifted</u> | <u>app. 50</u> | <u>G.P.M.</u> | |
| | | | |
| | | | |

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Potter Drilling Co. Contractor
 Address P.O. Box 1815 Contractor
 Nevada contractor's license number 020161
 Nevada contractor's drillers number 1348
 Nevada driller's license number 1348 Actual Driller
 Signed Jim Potter Contractor
 Date 8-3-90

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. -- Draw down -- feet -- hours
 G.P.M. _____ Draw down _____ feet _____ hours