WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 34502
Permit No.
Basin 230

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 5974

1. OWNER Bond Gold
MAILING ADDRESS Beatty, NV
ADDRESS AT WELL LOCATION Beatty, NV

2. LOCATION SW ¼ SE ¼ Sec. 7 T. 13 S N R. 46 E. Nye County
PERMIT NO. (Issued by Water Resources) (Parcel No.) BGMW #3 (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☒
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Boulders		0	10	10
Cemented Gravel		10	20	10
Cobbles		20	40	20
Layers of cobbles cemented		40	130	90
Cemented Gravel & Cobbles		130	350	220
Hard Cemented Gravel		350	460	110
Cemented Gravel & Quartz		460	600	140
Cemented Gravel	X	600	780	180
Cobble Layers with Clay				
Clay & Sand	X	780	800	20
Cemented Gravel		800	940	140

RECEIVED
NOV 9 1989
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started July 20, 1989
Date completed July 27, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 12 1/4 inches Total depth 940 feet
9 7/8 inches
9 7/8 inches
Casing record 6 5/8
Weight per foot ..... Thickness .188

Diameter	From	To
6 5/8 inches	+ 2 feet	940 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 940 feet

Perforations:
Type perforation Factory Cut
Size perforation 1/8-3 6 Rows
From 920 feet to 940 feet
From 880 feet to 900 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 561 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature ..... °F Quality .....

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WATER Well Services (Contractor)
Address 4545 N. Rancho LV. (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 22311
Nevada contractor's driller's number issued by the Division of Water Resources 694
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1559
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 11-2-89

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627