WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 34514
Permit No. 53876
Basin 212

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 8572

1. OWNER AL JAWORSKI
MAILING ADDRESS N/A
ADDRESS AT WELL LOCATION N/A

2. LOCATION NW ¼ NE ¼ Sec 6 T 20S X/S R 60 E CLARK County
PERMIT NO. 53876 (Issued by Water Resources) | N/A (Parcel No.) | N/A (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☒ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| LOOSE GRAVEL | | 0 | 19 | |
| CEMENTED GRAVEL | | 19 | 23 | |
| CLAY GRAVEL | | 23 | 360 | |
| BOULDERS | | 360 | 420 | |
| CLAY+GRAVEL | | 420 | 510 | |
| GRAVEL + WATER | | 510 | 600 | |

RECEIVED
SEP 12 1990
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 7/13, 19 90
Date completed 7/20, 19 90

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | | | |

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 12¼ inches Total depth 600 feet
..... inches
..... inches
Casing record
Weight per foot ..... Thickness 156

| Diameter | From | To |
|---|---|---|
| 8 5/8 inches | +1 feet | 600 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☒ No ☐ Type CEMENT
Depth of seal 55 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from N/A feet to ..... feet

Perforations:
Type perforation FACTORY
Size perforation 3/16 X 6 ROW
From 560 feet to 580 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 490 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature ..... °F Quality .....

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name VERNON DIMICK (Contractor)
Address 7115 ROGERS (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 10062
Nevada contractor's driller's number issued by the Division of Water Resources 552
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552
Signed V. Dimick (By driller performing actual drilling on site or contractor)
Date 9/5 90

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (D)-027