WELL NO. 72

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 34515
Permit No. 53816-T
Basin 212

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 13071

1. OWNER Las Vegas Valley Water Dist.
MAILING ADDRESS 3700 West Charleston Blvd.
Las Vegas, Nevada 89104

ADDRESS AT WELL LOCATION Fronts W. side Buffalo Dr
Buffalo and Cheyenne (1)West on Cheyenne Rd
from Expressway (north)about .30 mile North

2. LOCATION NE ¼ SE ¼ Sec. 9 T 20S N/S R 60E E Clark County
PERMIT NO. 53816-T
Issued by Water Resources | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well XX Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal XX Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☐
Other XX REverse

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy gravels, 65% to 70% gravels consist of sell graded, sub-angular to subrounded, dark to lite gray limestones, etc. See the attached 3 pages) for Well No. 72		0	56 ft.	

RECEIVED
AUG 10 1990
Div. of Water Resources
Branch Office - Las Vegas NV

RECEIVED
STATE ENGINEER'S OFFICE
'90 AUG -8 A10:27

Date started Sept 23, 1989, 19
Date completed Oct. 20, 1989, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	3000	261	15

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter 30 inches Total depth 1595 feet
inches
inches
Casing record
Weight per foot Thickness

Diameter	From	To
20 inches	0 feet	855 feet
20 inches	1175 feet	1295 feet
20 inches	1575 feet	1595 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes XX No ☐ Type cement grout
Depth of seal 150 ft feet
Gravel packed: Yes XX No ☐
Gravel packed from 0 feet to 1595 feet

Perforations:
Type perforation Roscoe Moss Ful Flo shutter scree
Size perforation 0.156 louver
From 855 feet to 1175 feet
From 1295 feet to 1575 feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 373 feet below land surface
Flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name BEYLIK DRILLING, INC. Contractor
Address 591 S. Walnut St., La Habra, Cal. 90631 Contractor
Nevada contractor's license number issued by the State Contractor's Board 0007055-A C-23
Nevada contractor's driller's number issued by the Division of Water Resources 1244
Nevada driller's license number issued by the Division of Water Resources the on-site driller
Signed Robert A. Beylik
By driller performing actual drilling on site or contractor
Date May 4, 1990

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627