WELL NO. 68

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 34570
Permit No. 53729-T
Basin

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 13079

1. OWNER Las Vegas Valley Water Dist.
MAILING ADDRESS 3700 West Charleston Blvd.
Las Vegas, Nevada 89153

ADDRESS AT WELL LOCATION Valley View Blvd. at Alta Dr. Access by dirt road North off of Alta Drive, (Dist No. Well Field)

2. LOCATION SE ¼ NE ¼ Sec. 31 T. 20S N/S R. 61 E. Clark County
PERMIT NO. 53729-T
Issued by Water Resources | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☒ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☐
Other ☒ Reverse

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy silt unconsolidated		0	2 ft	
Caliche, bedded light buff to white		2	4 ft.	
balance log continued on the attached Lithology Logs (7 pages)				

RECEIVED
AUG 10 1990
Div. of Water Resources
Branch Office - Las Vegas, NV

90 AUG -8 A10:26
STATE ENGINEER

Date started July 5, 1989, 19
Date completed August 15, 1989, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	3300	54.5	12

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter 30 inches Total depth 970 feet
inches
inches
Casing record
Weight per foot Thickness

Diameter	From	To
20 inches	+3 feet	270 feet
20 inches	370 feet	530 feet
20 inches	930 feet	970 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Concrete grout seal
Depth of seal 140 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 200 feet to 970 feet

Perforations:
Type perforation Johnson HiCap Triple Extra Stron
Size perforation 0.100 slots
From 270 feet to 370 feet
From 530 feet to 930 feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 207 feet below land surface
Flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name BEYLIK DRILLING, INC
Contractor
Address 591 S. Walnut Street La Habra, Calif. 90631
Contractor
Nevada contractor's license number issued by the State Contractor's Board 0007055A C23
Nevada contractor's driller's number issued by the Division of Water Resources 1244
Nevada driller's license number issued by the Division of Water Resources, the on-site driller
Signed Robert S. Beylik
By driller performing actual drilling on site or contractor
Date May 4, 1990

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627