



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.370 and NAC 534.340

NOTICE OF INTENT NO. 11962

1. OWNER Georgia Pacific ADDRESS AT WELL LOCATION Apex Plant  
 MAILING ADDRESS Post Office Box 30006  
No. Las Vegas, NV 89036-0006  
 2. LOCATION SW  $\frac{1}{4}$  NE  $\frac{1}{4}$  Sec. 34 T. 18 S. 63 E. Clark County  
 PERMIT NO. 50316 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other Ream

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  
 Other

6. LITHOLOGIC LAB

Material	Water Strata	From	To	Thickness
<u>See previous log on test drilling (copy attached)</u>				
<u>Bottom of <del>ream</del> borehole abandoned with 30 sks neat cement</u>		<u>1200</u>	<u>1250</u>	

RECOMMENDED

NOV 20 1992

CLARK COUNTY DIVISION OF WATER RESOURCES  
 2000 W. LAS VEGAS, NV  
 702-733-1100

8. WELL CONSTRUCTION  
 Total Depth 1200 Feet  
 HOLE DIAMETER (BIT SIZE)  

	From	To
<u>26</u> Inches	<u>0</u> Feet	<u>50</u> Feet
<u>15</u> Inches	<u>50</u> Feet	<u>500</u> Feet
<u>12 1/2</u> Inches	<u>500</u> Feet	<u>1200</u> Feet

 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>		<u>.250</u>	<u>+1</u>	<u>1200</u>

 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50'  Neat Cement  
 Placement Method:  Pumped  Poured  Cement Grout  Concrete Grout  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ Feet to \_\_\_\_\_ Feet

9. WATER LEVEL  
 Static water level \_\_\_\_\_ feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name THOMPSON DRILLING CO., INC. Contractor  
 Address 4785 West Harmon Contractor  
Las Vegas, NV 89103

Nevada contractor's license number issued by the State Contractor's Board 4286A  
 Nevada contractor's driller's number issued by the Division of Water Resources 290  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 856  
 Signed Richard K. Thompson  
 By driller performing actual drilling on site or contractor  
 Date November 18, 1992

Date started September 8, 1992  
 Date completed October 23, 1992

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>140</u>	<u>10"</u>	<u>4</u>