


OFFICE USE ONLY
 Log No. **34537**
 Permit No. _____
 Basin. **162**



WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. **8522**

PRINT OR TYPE ONLY

1. OWNER Bill Moore ADDRESS AT WELL LOCATION Simkin RD
 MAILING ADDRESS _____ Pahrump, NV

2. LOCATION SE 1/4 SE 1/4 Sec 19 T. 19S N/S R. 53 E. NYE County _____
 PERMIT NO. n/a Issued by Water Resources Parcel No. _____ Subdivision Name Lot 121 Valley View Acres

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
clay		0'	10'	10'
caliche		10'	12'	2'
clay		12'	20'	8'
caliche		20'	22'	2'
clay		22'	34'	12'
caliche		34'	37'	3'
clay		37'	51'	14'
caliche	WB	51'	53'	2'
clay		53'	59'	6'
caliche	WB	59'	63'	4'
clay		63'	68'	5'
caliche	WB	68'	76'	8'
clay		76'	92'	16'
caliche	WB	92'	97'	5'
clay		97'	114'	17'
caliche	WB	114'	116'	2'
clay		116'	120'	4'

8. WELL CONSTRUCTION

Diameter 12 1/4 inches Total depth 120' feet
 _____ inches
 _____ inches

Casing record 120' x 8 5/8"
 Weight per foot 14.11 Thickness 156

Diameter	From	To
<u>8 5/8</u> inches	<u>0</u> feet	<u>120</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type concrete
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 100 feet to 50 feet

Perforations:
 Type perforation factory sawcut
 Size perforation 1/8" x 3"
 From 120 feet to 100 feet
 From _____ feet to _____ feet

Date started 7-30, 1990
 Date completed 8-3, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL

Static water level 45 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name GREAT BASIN DRILLING
 Contractor
 Address Hcr 65 Box 80358 Pahrump, NV 89041
 Contractor
 Nevada contractor's license number 30880
 issued by the State Contractor's Board
 Nevada contractor's driller's number 1426
 issued by the Division of Water Resources
 Nevada driller's license number issued by the Division of Water Resources the on-site driller
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 9-12-90



RECEIVED
 SEP 21 1990
 Div. of Water Resources
 Branch Office - Las Vegas, NV