WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

EBP-2
PRINT OR TYPE ONLY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 34555
Permit No. 55269
Basin 215

NOTICE OF INTENT NO. 3543

1. OWNER Bonneville Energy
MAILING ADDRESS c/o Mifflin & Associates
2700 E. Susnet, Suite C-25, Las Vegas, NV 89120

ADDRESS AT WELL LOCATION Gypsum Wash

2. LOCATION ~~NE~~ SE SE ¼ Sec. 13 T. 19 S R. 63 E. Clark County
PERMIT NO. 55269 (Issued by Water Resources) Parcel No. Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☒
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Cemented limestone		0	325	325
Clay with limestone		325	430	105
Frac. limestone w/iron		430		
oxide & traveertine			475	45
Cem. quartz & limestone		475	575	100
Quartz, lt. grey limestone		575		
& clayey limestone			630	55
Limestone, dolomite w/red		630		
to brn. sandstone			780	150
Fractured w/travertine		780	800	20
Lt. to dk. grey limestone		800	1214	414

RECEIVED
OCT 05 1990
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started March 27, 19 90
Date completed June 12, 19 90

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours

8. WELL CONSTRUCTION
Diameter ____ inches Total depth 1,214 feet
17 inches to 997'
12 inches to 1,214
Casing record
Weight per foot ____ Thickness .279

Diameter	From	To
12 1/8 inches	+1 feet	997 feet
8 1/8 inches	974 feet	1,214 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 60 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from ____ feet to ____ feet

Perforations:
Type perforation Mill slots (8" single cut - 12" double cut)
Size perforation 1/2 x 2 1/2"
From 755 feet to 1,214 feet
From 12" - 755 feet to 960 feet
From 8" - 974 feet to 1,214 feet
From ____ feet to ____ feet
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 575 feet below land surface
Flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name THOMPSON DRILLING CO., INC. (Contractor)
Address 4185 W. Harmon Las Vegas, NV 89103 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 4286A
Nevada contractor's driller's number issued by the Division of Water Resources 290
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 856
Signed Richard Thompson
By driller performing actual drilling on site or contractor
Date October 4, 1990

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627