

OFFICE USE ONLY
 Log No. 39558
 Permit No. 162
 Basin 162

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 8618
Basin Road

PRINT OR TYPE ONLY

1. OWNER DOTTIE JEPSON ADDRESS AT WELL LOCATION Basin Road
 MAILING ADDRESS _____
 2. LOCATION NE 1/4 NW 1/4 Sec 14 T 20s N/S R 52 E NYE County
 PERMIT NO. N/A Issued by Water Resources Parcel No. _____ Subdivision Name Golden Springs Ranch Unit 3 Lot 4

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
clay		0'	18'	18'
caliche		18'	20'	2'
limestone		20'	35'	15'
clay		35'	40'	5'
caliche		40'	44'	4'
clay		44'	55'	11'
caliche	WB	55'	58'	3'
clay		58'	63'	5'
caliche	WB	63'	65'	2'
clay		65'	69'	4'
caliche	WB	69'	74'	5'
clay		74'	80'	6'
caliche	WB	80'	88'	8'
clay		88'	97'	9'
caliche	WB	97'	105'	8'
clay		105'	112'	7'
caliche	WB	112'	119'	7'
clay		119'	123'	4'
caliche	WB	123'	126'	3'
clay		126'	135'	9'
caliche	WB	135'	138'	3'
clay		138'	140'	2'

8. WELL CONSTRUCTION
 Diameter 12 1/2 inches Total depth 140 feet
 _____ inches
 _____ inches
 Casing record 140' X 8 5/8"
 Weight per foot 14.11 Thickness .156

Diameter	From	To
<u>8 5/8</u> inches	<u>0</u> feet	<u>140'</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type concrete
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 140 feet to 50 feet
 Perforations:
 Type perforation factory sawcut
 Size perforation 1/8" X 3"
 From 140 feet to 120 feet
 From _____ feet to _____ feet

Date started 9-14 1990
 Date completed 9-17 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL
 Static water level 40' feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature cool F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name GREAT BASIN DRILLING Contractor
 Address HCR 65 BOX 80358 PAHRUMP, NEVADA 89041
 Nevada contractor's license number 30880 issued by the State Contractor's Board
 Nevada contractor's driller's number 1426 issued by the Division of Water Resources
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573
 Signed [Signature] By driller performing actual drilling on site or contractor
 Date 9-21-90

RECEIVED
 OCT 01 1990
 Div. of Water Resources
 Branch Office - Las Vegas, NV
 WATER TEST

