

OFFICE USE ONLY
 Log No. 34564
 Permit No. _____
 Basin _____

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 8748

PRINT OR TYPE ONLY

1. OWNER HAL FINCHER ADDRESS AT WELL LOCATION "D" South & Barney
 MAILING ADDRESS _____

2. LOCATION SE $\frac{1}{4}$ NE $\frac{1}{4}$ Sec. 24 T. 20s N/S R. 52 E. NYE County
 PERMIT NO. n/a 28-785-02 Charleston Park Ranchoes Unit 6 Lot 130
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock Other

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
clay		0'	7'	7'
calichie		7'	8'	1'
clay		8'	15'	7'
calichie		15'	18'	3'
clay		18'	32'	14'
calichie		32'	34'	2'
clay		34'	56'	22'
calichie	WB	56'	60'	4'
clay		60'	73'	13'
calichie	WB	73'	76'	3'
clay		76'	84'	8'
calichie	WB	84'	86'	2'
clay		86'	92'	6'
calichie	WB	92'	94'	2'
clay		94'	98'	4'
calichie	WB	98'	102'	4'
clay		102'	115'	13'
calichie	WB	115'	118'	3'
clay		118'	129'	11'
calichie	WB	129'	132'	3'
clay		132'	140'	8'

8. WELL CONSTRUCTION
 Diameter 12 1/2 inches Total depth 140' feet
 _____ inches
 _____ inches
 Casing record 140' x 8 5/8"
 Weight per foot 14.11 Thickness .156

Diameter	From	To
<u>8 5/8"</u> inches	<u>0</u> feet	<u>140</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type concrete
 Depth of seal 50; feet
 Gravel packed: Yes No
 Gravel packed from 140 feet to 50 feet
 Perforations:
 Type perforation factory sawcut
 Size perforation 1/8" x 3"
 From 140 feet to 100 feet
 From _____ feet to _____ feet

RECEIVED

OCT 29 1990

Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started 9-26, 1990
 Date completed 10-1, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL
 Static water level 4.3 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature 90.2 °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name GREAT BASIN DRILLING
Contractor
 Address HCR 65 box 80358 Pahrump, Nv 89041
Contractor
 Nevada contractor's license number issued by the State Contractor's Board 30880
 Nevada contractor's driller's number issued by the Division of Water Resources 1426
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573
 Signed [Signature]
By driller performing actual drilling on site or contractor
 Date 10-12-90

