WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 34573
Permit No. 54673
Basin 212

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 5234

1. OWNER Michael Donovan
MAILING ADDRESS 6010 W. Cheyenne #15-205
LV, Nv. 89108

ADDRESS AT WELL LOCATION
craig rd. & El Capitan

2. LOCATION SE ¼ NW ¼ Sec. 5 T. 20 N/S R. 60 E clark County
PERMIT NO. 54673 (Issued by Water Resources) | 450-030-017 (Parcel No.) | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
silt sand & gravel				
part. cemented		0	110	110
sand & gravel		110	148	38
gray clay sand & gravel		148	222	74
sand & gravel		222	400	178
cemented sand & gravel	330	400	440	40
sand & gravel		440	539	99
cemented sand & gravel		539	600	61

RECEIVED
OCT 18 1990
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 9-28, 19 90
Date completed 10-8, 19 90

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
air	40	?	1

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 10 inches Total depth 600 feet
..... inches
..... inches
Casing record 6 5/8"
Weight per foot 12.92 Thickness .188

Diameter	From	To
6 5/8 inches	0 feet	600 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement
Depth of seal 90 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation Torch
Size perforation 1/4 x 6" x 3 around
From 400 feet to 600 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 330 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Allen Drilling, Inc. (Contractor)
Address 4847 So. Valley View Blvd. (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0018917
Nevada contractor's driller's number issued by the Division of Water Resources 1301
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1661
Signed Donald L Wall (By driller performing actual drilling on site or contractor)
Date

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627