

OFFICE USE ONLY  
 Log No. 34594  
 Permit No. 1  
 Basin 1  
 NOTICE OF INTENT NO. 4141

PRINT OR TYPE ONLY

WELL DRILLER'S REPORT

Please complete this form in its entirety

OWNER James White ADDRESS AT WELL LOCATION Vickie Ann  
 MAILING ADDRESS \_\_\_\_\_

2. LOCATION NW 1/4 NW 1/4 Sec. 13 T. 21s N/S R. 53 E NYE County  
 PERMIT NO. n/a Issued by Water Resources 44-583-19 Parcel No. Lot 7 Block 2 Conestoga Estates Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
clay		0'	15'	15'
calichie		15'	18'	3'
clay		18'	26'	8'
calichie		26'	28'	2'
clay		28'	33'	5'
calichie		33'	39'	6'
clay		39'	45'	6'
calichie		45'	47'	2'
clay		47'	50'	3'
calichie		50'	56'	6'
clay		56'	60'	4'
calichie	WB	60'	63'	3'
clay		63'	70'	7'
calichie	WB	70'	72'	2'
clay		72'	77'	5'
calichie	WB	77'	86'	9'
clay		86'	109'	23'
calichie	WB	109'	111'	2'
clay		111'	119'	8'
calichie	WB	119'	121'	2'
clay		121'	126'	5'
calichie	WB	126'	129'	3'
clay		129'	132'	3'
calichie	WB	132'	134'	2'
clay		134'	136'	2'
limestone	WB	136'	140'	4'

Date started 10-10 1990  
 Date completed 10-13 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

8. WELL CONSTRUCTION  
 Diameter 12 1/2 inches Total depth 140' feet  
 \_\_\_\_\_ inches  
 \_\_\_\_\_ inches  
 Casing record 140' x 8 5/8"  
 Weight per foot 16.94 Thickness .188  
 \_\_\_\_\_ diameter From \_\_\_\_\_ To \_\_\_\_\_  
8 5/8 inches \_\_\_\_\_ 0 feet \_\_\_\_\_ 140 feet  
 \_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
 Surface seal: Yes  No  Type concrete  
 Depth of seal 50' feet  
 Gravel packed: Yes  No   
 Gravel packed from 140 feet to 50 feet  
 Perforations:  
 Type perforation factory sawcut  
 Size perforation 1/8" x 3"  
 From 140 feet to 120 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 53 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COOL °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name GREAT BASIN DRILLING  
 Contractor  
 Address HCR 65 box 80358 Pahrump, Nv 89041  
 Contractor  
 Nevada contractor's license number 30880  
 issued by the State Contractor's Board  
 Nevada contractor's driller's number 1426  
 issued by the Division of Water Resources  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 10-19-90

RECEIVED  
 OCT 23 1990