WHITE–DIVISION OF WATER RESOURCES
CANARY–CLIENT'S COPY
PINK–WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 34608
Permit No.
Basin 212

In Book C

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 15976

1. OWNER Mr. Bob Glennon
MAILING ADDRESS 3060 W. Business Ln
Las Vegas, Nevada 89103

ADDRESS AT WELL LOCATION 3060 W. Business Ln
Las Vegas, Nevada 89103

2. LOCATION SE ¼ NW ¼ Sec. 20 T. 21S N/S R. 61 E Clark County
PERMIT NO. ____ Issued by Water Resources | Parcel No. | Subdivision Name

3. TYPE OF WORK: New Well XX; Recondition ☐; Deepen ☐; Other ☐

4. PROPOSED USE: Domestic ☐; Irrigation ☐; Test XX; Municipal ☐; Industrial ☐; Stock ☐

5. TYPE WELL: Cable ☐; Rotary XX; Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy/Silty Gravel		0	5.5	5.5
Caliche	11.5	5.5	16.5	11.0
Silty to Sandy Clay	29.0	16.5	40	

RECEIVED
OCT 24 1990
Div. of Water Resources
Branch Office - Las Vegas, NV

STATE ENGINEER'S OFFICE
90 OCT 22 AM 10:33

Date started September 11, 1990
Date completed September 13, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Monitor			

BAILER TEST
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours

8. WELL CONSTRUCTION
Diameter 4 inches Total depth 38.0 feet
____ inches
____ inches
Casing record 8 inch PVC Surface Casing
Weight per foot ____ Thickness 0.375 inch
Diameter 4 inch sched 40 PVC

Diameter	From	To
8 inches	0 feet	19 feet
4 inches	0 feet	23.0 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☐ No XX Type waiver
Depth of seal 0-17 grout, 17-21.5 bentonite feet
Gravel packed: Yes XX No ☐ No. 12 Silica
Gravel packed from 21.5 feet to 40 feet

Perforations:
Type perforation Manufacturer
Size perforation 0.020 inch
From 23.0 feet to 36.9 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 9.67 feet below land surface
Flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality ____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Dave's Drilling Company (Contractor)
Address 5617 W. Wells Park Road, West Jordan, Utah 84088 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 980558
Nevada contractor's driller's number issued by the Division of Water Resources 1706
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1706
Signed Dick Armstrong
By driller performing actual drilling on site or contractor
Date 9-13-90

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O-627)