WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 34654
Permit No. 54451
Basin 212

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 8591

1. OWNER Norman W. E. Mott
MAILING ADDRESS
ADDRESS AT WELL LOCATION

2. LOCATION SE ¼ NE ¼ ¼ Sec. 14 T. 19 N. R. 60 E. CLARK County
PERMIT NO. 54451 (Issued by Water Resources) Parcel No. Subdivision Name

3. TYPE OF WORK: New Well ☑ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☐ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐ Q M.

5. TYPE WELL: Cable ☐ Rotary ☑ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BRN CLAY		0	110	110
BRN CLAY-GRAVEL		110	170	60
BRN CLAY-STONE	✓	170	180	10
BRN CLAY		180	460	80
CLAY + GRAVEL	✓	460	475	15
CLAY		475	500	25
CLAY STONE	✓	500	580	80

RECEIVED
NOV 1 1990
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 10-27, 1990
Date completed 11-1, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
AIR TEST			
900 CFM @ 250 PSI			
3 hr. development		580 ft	
40 GPM			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 9 7/8 inches Total depth 580 feet
..... inches
..... inches
Casing record
Weight per foot ..... Thickness .188

Diameter	From	To
6 inches	+ 1½ feet	580 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Cement
Depth of seal 50 ft feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 50 feet to 580 feet

Perforations:
Type perforation torch
Size perforation 1/4 x 12"
From 480 feet to 580 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 130 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature COLD °F Quality Okay.

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Steve Mitchell (Contractor)
Address 630 Rutter Ave S.D. 89124 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 28030
Nevada contractor's driller's number issued by the Division of Water Resources 1475
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1475
Signed Steve Mitchell (By driller performing actual drilling on site or contractor)
Date 11-1-90

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627