WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 34688
Permit No.
Basin 107

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 13513

1. OWNER Charles Picco
MAILING ADDRESS 20 Pinion Dr.
Wellington, NV. 89444

ADDRESS AT WELL LOCATION 20 Pinion Dr.
Wellington, NV. 89444

2. LOCATION NE ¼ SW ¼ Sec. 10 T. 11 N/S R. 23 E. Lyon County
PERMIT NO. ____ Issued by Water Resources | 09-051-04 Parcel No. | Valley View Ranchos Lot #20 Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil DG + Rock		0	5	5
DG Solid		5	55	50
DG Fracted		55	70	15
DG Solid		70	90	20
DG Light Fracted		90	99	9
DG Fracted		99	112	13
DG Light Fracted		112	120	8
DG Solid		120	125	5
DG Fracted with Clay	X	125	150	25
DG Fracted	X	150	165	15
DG Fracted with Clay	X	165	195	30
DG Fracted	X	195	205	10
DG Fracted with Bluesh Gray Clay		205	212	7
DG Light Fracted with Bluesh Gray Clay		212	235	23
DG Fracted Very Small amount of Clay	X	235	257	22

Date started 8-2, 1990
Date completed 8-15, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 22 Draw down 7 feet ½ hours
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours

8. WELL CONSTRUCTION
Diameter 12 5/8 inches Total depth 258' feet
____ inches
____ inches
Casing record
Weight per foot ____ Thickness .156

Diameter	From	To
8 5/8 inches	+1 feet	257 feet
____ inches	____ feet	____ feet
____ inches	____ feet	____ feet
____ inches	____ feet	____ feet
____ inches	____ feet	____ feet
____ inches	____ feet	____ feet

Surface seal: Yes ☒ No ☐ Type Cement Grout
Depth of seal 50' feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 257 feet

Perforations:
Type perforation Sawed
Size perforation 3/32" X 3"
From 157 feet to 177 feet
From 237 feet to 257 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 122' feet below land surface
Flow ____ G.P.M. ____ P.S.I.
Water temperature Cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ogden Bros Drilling (Contractor)
Address 162 N. Bybee Lane Yerington (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 15646
Nevada contractor's driller's number issued by the Division of Water Resources 634
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
Signed Terry Ogden (By driller performing actual drilling on site or contractor)
Date 8-15-90

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627