WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 34708
Permit No.
Basin 8-105

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 14508

1. OWNER WESTLAND CONSTRUCTION
MAILING ADDRESS 1120 Azul
Gardnerville, Nevada 89410

ADDRESS AT WELL LOCATION 1651 Finch
Gardnerville, Nv 89410

2. LOCATION SW ¼ SE ¼ Sec. 29 T. 13 N/S R. 21 E. Douglas County
PERMIT NO. (Issued by Water Resources) 23-150-24 (Parcel No.) None (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	4	4
Clay, fairly tight		4	28	24
Pea gravels, loose		28	60	32
Fine grainedd, hard, sandstone		60	75	15
Gravels, loose, with medium grained sand Water bearing from 125 to bottom	xx	75	160	85

total depth: 160 feet

Note: Ran a 10 foot blank on bottom of casing string.

Date started Oct 3, 1990
Date completed Oct 5, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Flushed mud from well and graveled well with pea gravel. Developed well with air for 3 hours. Blew 23 gpm from 125 feet			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 11½ inches Total depth 160 feet
9½ inches
inches
Casing record Steel 6 5/8"
Weight per foot 13.03 Thickness .188

Diameter	From	To
6 5/8 inches	2 feet	160 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Concrete
Depth of seal 60 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 60 feet to 160 feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 3" x 3/32"
From 130 feet to 150 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 87 feet below land surface
Flow 23 G.P.M. P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H PUMP CO. (Contractor)
Address CARSON CITY, NV. (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 23295
Nevada contractor's driller's number issued by the Division of Water Resources
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1674
Signed [signature] (By driller performing actual drilling on site or contractor)
Date Oct 6, 1990

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627