WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 34710
Permit No.
Basin 9-108

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 13508

1. OWNER Stan Shaffer
MAILING ADDRESS 23 Cherry Lane Yerington Lane
ADDRESS AT WELL LOCATION 23 Cherry Lane Yerington NV 89447

2. LOCATION NW ¼ SW ¼ Sec. 11 T. 13 N/S R. 25 E. Lyon County
PERMIT NO. (Issued by Water Resources) 04-292-12 (Parcel No.) (Subdivision Name)

3. TYPE OF WORK: New Well ☒ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☒ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☒ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil/Dirt		0	2	2
Fine To Coarse Sand		2	30	28
Fine To Carse Sand				
Green Clay		30	50	20
Coarse Sand +				
Gravel	X	50	62	12
Coarse Sand +				
Gravel Brown				
Clay		62	68	6
Coarse Sand +				
Gravel	X	68	75	7
Coarse Sand +				
Gravel Gray				
Clay		75	82	7
Coarse Sand,				
Gravel, Few				
Rocks		82	99'6"	17'6"

'90 OCT 23 A9:38
STATE ENGINEER'S OFFICE '90 NOV -7 A10:25

Date started 10-9, 1990
Date completed 10-12, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 22 Draw down 4 feet ½ hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter 11¼ inches Total depth 100'6" feet
inches
inches
Casing record
Weight per foot Thickness .156

Diameter	From	To
6 3/8 inches	+1 feet	99'6" feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type 10 Sack Cement Grout
Depth of seal 50 Placed 50' up feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 99'6" feet

Perforations:
Type perforation Sawed
Size perforation 3/32 x 3"
From 79'6" feet to 99'6" feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 17 feet below land surface
Flow G.P.M. P.S.I.
Water temperature Cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ogden Bros Drilling (Contractor)
Address 162 N By Bee Lane Yerington (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 15646
Nevada contractor's driller's number issued by the Division of Water Resources 634
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
Signed Ogden Bros Drilling Jay Ogden (By driller performing actual drilling on site or contractor)
Date 10-12-90

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O) 627