WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PROBABLY 003-210-070

PRINT OR TYPE ONLY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 34712
Permit No.
Basin 6-90

NOTICE OF INTENT NO. 14254

1. OWNER Tom Allen
MAILING ADDRESS P.O. 1960
Zepher Cove NV
ADDRESS AT WELL LOCATION 1141 Hyney 50'

2. LOCATION SW ¼ SE ¼ Sec. 34 T. 14 N/S R. 18 E. Douglas County

PERMIT NO. ____ Issued by Water Resources | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil	NO	1	3	3
Decomposed granite	NO	3	20	17
Hard granite	NO	20	70	50
Med Hard granite	yes	70	110	40
Hard granite	NO	110	120	10

'90 NOV -6 AM 10:02
STATE ENGINEER

Date started Oct 21, 1990
Date completed Oct 22, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	8 By air lift		
	1 Hr		

BAILER TEST
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours

8. WELL CONSTRUCTION
Diameter 10 inches Total depth 120 feet
____ inches
____ inches
Casing record 6
Weight per foot .16 Thickness .188

Diameter	From	To
6 inches	+1 feet	120 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 120 feet

Perforations:
Type perforation Factory
Size perforation 5/32
From 100 feet to 120 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 50 feet below land surface
Flow — G.P.M. — P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Endlco Inc
Contractor
Address P.O. 92, Smith Nv
Contractor
Nevada contractor's license number issued by the State Contractor's Board 24149
Nevada contractor's driller's number issued by the Division of Water Resources
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 718T-1
Signed [signature]
By driller performing actual drilling on site or contractor
Date Oct 22 1990

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627